


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

<input checked="" type="checkbox"/> Location of well:	County Grant	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 8	Township number T 29 S 30 R	Range number 35	E/W
2. Distance and direction from nearest town or city: from Hickok-- 1 mile east 7 south 2 3/4 east.			3. Owner of well: Lon Brollier R.R. or street: RFD 2, Ulysses, Ks. 67880 City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:			6. Bore hole dia. 9 3/4" Completion date 3/19/79 Well depth 318 ft.			
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material			From	To	9. Casing: Material styrene Height: Above or below glued and riveted Surface 18 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 278 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 320	
Surface			0	2	10. Screen: Manufacturer's name Sunflower Type styrene Dia. 5" Slot/gauze 1/16" Length 40 Set between 278 ft. and 318 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"	
Clay			2	35	11. Static water level: <input type="checkbox"/> mo./day/yr. 190 ft. below land surface Date 4/18/79	
Medium to coarse sand			135	60	12. Pumping level below land surfaces: 200 ft. after 6 hrs. pumping 3 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m.	
Yellow & gray clay			60	105	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.	
Medium to coarse sand w/clay breakers			105	265	14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade	
Sandy clay			265	297	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Medium to coarse sand			297	310	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Sandy clay w/fine sand strips			310	320	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. License No. 164 Box 487 , Ulysses, Ks. 67880 Signed M. Beard Date 8/22/79 Authorized representative	
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5