



*The*  
**Professionals**

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Mesa Limited Partnership  
Grant County  
6-27-89

Location: NE $\frac{1}{4}$  8-30-35  
From Hickock - 1 E., 7 S., 2 $\frac{1}{2}$  E.,  
100' S. & 519' E.

Static Water Level - 250'

## Test #1

0	3	Top soil
3	33	Brown clay
33	35	Fine sand - loose
35	54	Brown sandy clay - tight
54	95	Brown sandy clay - hard
95	116	Brown sandy clay - small sand streak
116	143	Brown clay - tight
143	146	Brown clay - small strip of gravel
146	151	Brown clay
151	170	Brown clay - white rock streak - tight
170	237	Brown clay
237	241	Fine to medium sand & gravel
241	256	Brown clay
256	263	Fine to medium sand & gravel
263	310	Fine to medium sand & gravel - hard
310	341	Brown sandy clay streak

**RECEIVED**

SEP 20 1989

DIVISION OF  
ENVIRONMENT