


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Grant County</b>	Fraction <b>1/4 1/4 NE 1/4</b>	Section number <b>10</b>	Township number <b>T 30 S R 35</b>	Range number <b>EW</b>
2. Distance and direction from nearest town or city: <b>North of Moscow on West side on black top, 7 North, 5 East, 2 North, 1/2 West, 1/2 South</b>		3. Owner of well: <b>Willie Christian (KI) RFD 2 Ulysses, KS 67880</b>		City, state, zip code:	
4. Locate with "X" in section below: Sketch map: 		6. Bore hole dia. <b>26</b> in. Completion date <b>9-31-77</b> Well depth <b>364</b> ft.			
5. Type and color of material		From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>364</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>.219</b>	
				10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Johnson Galv. 100-16"</b> Slot/gauze <b>0-240 Plain 240-260 Perf.</b> Set between <b>260-320 Screen 320-364 Perf.</b> ft. and <input type="checkbox"/> ft. Gravel pack? <b>Yes</b> Size range of material <b>1/4 to 5/8</b>	
				11. Static water level: <input type="checkbox"/> mo./day/yr. <b>200</b> ft. below land surface Date <b>9-31-77</b>	
				12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
				14. Well head completion: Pitless adapter <b>1 ft.</b> inches above grade	
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <b>N/A</b> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:  Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:  20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling Co. 208</b> Business name License No. Address <b>Box A, Garden City, KS 67846</b> Signed <b>Minter Wilson</b> Date <b>9-31-77</b> Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

July 29, 1977

Willis Christian

Location: NE $\frac{1}{4}$  10-30-35 North of Moscow on west side on black top, 7 mile North, 5 mile East, 2 mile North,  $\frac{1}{4}$  of a mile West and a  $\frac{1}{4}$  South, 150' Southeast of pivot

Static Water Level - 200

Test #

0	3	Top Soil
3	8	Black dirt
8	20	Brown Clay streak of sand
20	45	Brown Sandy Clay
45	105	Fine to med. sand and gravel (loose)
105	112	Med. coarse gravel
112	115	Brown Sandy Clay
115	203	Fine to med. sand gravel (loose)
203	208	Fine to med. sand and gravel small clay loose
208	245	Fine to med. sand (loose)
245	247	Yellow Clay
247	262	Blue Clay
262	275	Fine to med. sand
275	295	Fine to med. sand and fine gravel (loose)
295	322	Fine to med. sand and gravel
322	344	Brown Sandy Clay small gravel streak
344	364	Brown Sandy Clay 10% Gravel
364	383	Brown Sandy Clay
383	410	Brown Sandy Clay mixed with white rock hard
410	428	Brown Sandy Clay
428	441	Brown Sandy Clay small loose streak of brown and white rock no good
441	446	Brown Clay
446	457	Yellow Clay
457	465	Shale