

1. Location of well:		County Grant	Fraction $\frac{1}{4}$ NW $\frac{1}{4}$ NE $\frac{1}{4}$	Section number 20	Township number T 30 S	Range number R 35 E (W)
2. Distance and direction from nearest town or city: 10 south of Ulysses 10 3/4 EAST			3. Owner of well: Willis Christian R.R. or street: RR 2 City, state, zip code: Ulysses, KS 67880			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 2 1/2 in. Completion date _____ Well depth 413 ft.		
<div style="text-align:center;">N 1 Mile W E S 1 Mile</div>				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Overburden			0	9. Casing: Material Steel Height: Above or below surface _____ Threaded <input checked="" type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 42.5 lbs./ft. Dia. 1 1/2 in. to 4 1/2 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 250		
Top Soil			2	10. Screen: Manufacturer's name L.B. Foster Type Steel Dia. 1 1/2 Slot/gauze 1/8 Length 3 Set between 28-290 ft. and 330-360 ft. 380-400 ft. and 410-413 ft.		
Bn. Clay & Sd.		190	280	Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/8-1/4		
Med. Coarse Sd. w/Clay Strks.		280	330	11. Static water level: _____ mo./day/yr. 220 ft. below land surface Date 4/29/77		
Clay & Med. Sd.		330	360	12. Pumping level below land surfaces: NA _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Md. Coarse Sd.		360	380	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay & Med. Sd.		380	400	14. Well head completion: _____ Pitless adapter <input checked="" type="checkbox"/> _____ Inches above grade		
Med. & Fine Sd.		400	410	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Clay		410	415	16. Nearest source of possible contamination: _____ ft. _____ Direction _____ Type Field Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks: 10A Johnson IRR 16" Steel .1000 slot 290-330, 360-380, 400-410 10A Coop Land				
Topography: _____ <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KTM DRILLING, INC. 225 Business name _____ License No. _____ Address Box 1385, Guyman, OK 73041 Signed [Signature] Date 6/2/77 Authorized representative				