


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

NE 1/4 & NE 1/4

1 Location of well:	County Grant	Township name Sullivan	Fraction NE 1/4	Section number 21	Town number T30 S	Range number R35 W	
Distance and direction from nearest town or city: MOSCOW 7 West of SATANA			3 Owner of well: WILLIS CHRISTIAN Address: Ulysses, Kan				
Locate with "X" in section below: N 		Sketch map:		4 Well depth: 372 ft. Date of completion 2/13/75 Well diameter 26 in.			
2 Type and color of material		From		To			
		Top Soil		0		2	
		Overburden		2		120	
		Clay		120		175	
		Med. Coarse Sd.		175		220	
		Gravel, Coarse Sd. & Clay Strks.		220		300	
		Coarse Sd.		300		350	
		Med. Coarse Sd. w/Clay Strks.		350		370	
Yellow Clay & Red Clay		370		400	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
				7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 372 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 42.5 lbs./ft. L			
				8 Screen: J.B. Foster Type Steel Dia. 16" Slot/gauze 1/8" Length 3" Set between 166 ft. and 320 ft. Fittings: 372 340 372 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8 to 1/4			
				9 Static water level: 92 ft. below land surface Date 2-15-75			
				10 Pumping level below land surfaces: NA ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____			
				12 Well head completion: 12 <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.			
				14 Nearest source of possible contamination: Pasture ft. ____ Direction ____ Type land Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: Pump Set By Third Party <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation		17 Water well contractor's certification:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KTM DRILLING, INC. 225 Business name License No. Address Box 1385, Gorman, Okla. Signed Anthony Heiber Date 2/11/75 Authorized representative					

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5