

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 23	Township number T 30 S R 36	Range number 36
2. Distance and direction from nearest town or city: 9 miles south, 1 East, 1 south				3. Owner of well: Tex Demuth R.R. or street: RFD 2 City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 9 1/2 in. Completion date _____ Well depth 260 ft. 9-15-77	
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	2	9. Casing: Material styrene (Above or below) Threading glued Surface 12 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 220 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 320		
Very fine sand w/clay breakers		2	30	10. Screen: Manufacturer's name _____ Sunflower Type styrene Dia. 5" Slot/gauze 1/16" Length 40 Set between 220 ft. and 260 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"		
Brown sandy clay		30	141	11. Static water level: _____ mo./day/yr. 145 ft. below land surface Date 9-9-77		
Medium to coarse sand w/clay breakers		141	157	12. Pumping level below land surfaces: 155 ft. after 5 hrs. pumping 25 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ NA _____ g.p.m.		
Brown sandy clay/w/fine sand strips		157	186	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Medium to coarse sand w/clay breakers		186	260	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 200 Direction east Type corral Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name _____ License No. _____ Address Box 487, Ulysses, Ks. 67880 Signed M. Beard Date 11-16-77 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 30 S R 36 E
 Sec 23
 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5