

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: Grant		$\frac{1}{4}$ $\frac{1}{4}$ NE $\frac{1}{4}$	36	T 30 S	R 36 E (W)
Distance and direction from nearest town or city street address of well if located within city? From Moscow 5 1/2 miles No. 3/8 mile SE in field					
2 WATER WELL OWNER: Gary Brewer RR#, St. Address, Box # : Moscow, Ks. City, State, ZIP Code : 67952 Board of Agriculture, Division of Water Resources Application Number:					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: 300 ft. ELEVATION:			
<div style="text-align: center;"><p>1 Mile</p></div>		Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft.			
		WELL'S STATIC WATER LEVEL 160 ft. below land surface measured on mo/day/yr 5-3-85			
		Pump test data: Well water was ft. after hours pumping gpm			
		Est. Yield gpm: Well water was ft. after hours pumping gpm			
		Bore Hole Diameter 10 5/8 in. to 300 ft., and in. to ft.			
WELL WATER TO BE USED AS:		5 Public water supply 8 Air conditioning 11 Injection well			
<input checked="" type="checkbox"/> Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)					
2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well					
Was a chemical/bacteriological sample submitted to Department? Yes.....No. X; If yes, mo/day/yr sample was submitted					
Water Well Disinfected? Yes X No					
5 TYPE OF BLANK CASING USED:					
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped					
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded X					
Blank casing diameter 6 7/8 in. to 260 ft., Dia. in. to ft., Dia. in. to ft.					
Casing height above land surface 12 in., weight 16.9 lbs./ft. Wall thickness or gauge No. 188					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement					
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)					
SCREEN OR PERFORATION OPENINGS ARE:					
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)					
2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes					
<input checked="" type="checkbox"/> Torch cut 10 Other (specify)					
SCREEN-PERFORATED INTERVALS: From 260 ft. to 300 ft., From ft. to ft.					
GRAVEL PACK INTERVALS: From 220 ft. to 300 ft., From ft. to ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other					
Grout Intervals: From 0 ft. to 10 ft., From ft. to ft., From ft. to ft.					
What is the nearest source of possible contamination:					
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well					
2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well					
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)					
Direction from well? How many feet?					
FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG					
Test log attached					
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <input checked="" type="checkbox"/> constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 5-4-85 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208 . This Water Well Record was completed on (mo/day/yr) 5-9-85 under the business name of Minter Wilson Drilling Co. by (signature) J. H. Sasseman					
INSTRUCTIONS: Use typewriter or ball point pen, PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Environmental Geology Section, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.					

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Gary Brewer

Grant Co.

5-3-85

Location: From Moscow $5\frac{1}{2}$ miles No. 1 $3\frac{3}{8}$ miles So.
East in field

Static water level 150'

Test # 1

0 5 Top soil 01
5 16 Fine sand 07
16 29 Brown sandy clay 04
29 64 Fine to medium sand 05
64 73 Fine to medium sand & gravel. Hard pull down 17
73 132 Brown caly 01
132 147 Brown clay & small gravel streak ~~17~~
147 155 Brown clay. 10% gravel 35
155 170 Gray clay 01
170 194 Brown sandy clay & small gravel streak
194 215 Fine to medium sand & gravel. Loose
215 220 Fine to medium sand & gravel. Tight 17
220 233 Brown clay, White rock mixed. Small hard streak 21
233 251 Brown sandy clay 04
251 258 Brown Yellow clay 01
258 263 Fine to medium sand & gravel 17
263 265 Brown clay 01
265 284 Fine to medium sand & gravel 17
284 290 Brown sandy clay
290 301 Brown sandy clay, small gravel strip
301 326 Brown sandy clay 04
326 334 Brown, Yellow clay. Clay hard 01
334 350 Yellow & Gray clay Sand streak 10% 04
350 365 Yellow, Gray & Brown clay 01