


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 6	Township number T 30 S R 37 E W	Range number 37
2. Distance and direction from nearest town or city: 7 miles south, 3 west, 1/4 south of Ulysses Street address of well location if in city:			3. Owner of well: Carl Johnson R.R. or street: RFD City, state, zip code: Johnson, Ks. 67855			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 26 in. Completion date 12/14/78 Well depth 490 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface		0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Brown clay		2	100	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.8 lbs./ft. Dia. 16 in. to 267.11 ft. depth Wall Thickness: inches or Dia. 16 in. to 267.11 ft. depth gage No. .219		
Fine sand		100	120	10. Screen: Manufacturer's name Lakewood Type steel Dia. 16" Slot/gauze 3/16" Length 222.1 ft. Set between 267.11 ft. and 490 ft. ft. and 490 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 5/8"		
Brown clay		120	150	11. Static water level: 189 ft. below land surface Date 12-14-78 mo./day/yr.		
Brown clay w/fine sand strips		150	185	12. Pumping level below land surfaces: 279 ft. after 15.2 hrs. pumping 1296 g.p.m. ft. after 255 hrs. pumping 1450 g.p.m. Estimated maximum yield 1450 g.p.m.		
Clay & sandy clay		185	255	13. Water sample submitted: 189 ft. below land surface Date 12-14-78 mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
Fine sand		255	275	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Medium sand w/clay strips 44 ft.		275	345	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Fine sand and clay		345	410	16. Nearest source of possible contamination: ft. field Direction field Type field Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
Fine sand and sandy clay 18 ft.		410	450	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Houck Bros. Drlg. Co. Model number Box 487, Ulysses, Ks. HP 164 Volts 164 Length of drop pipe 8/20/79 ft. capacity 164 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay w/fine sand strips		450	497	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. License No. 164 Address Box 487, Ulysses, Ks. Signed M. Beard Date 8/20/79 Authorized representative		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5