


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Grant</b>	Fraction <b>SE 1/4 NE 1/4 NE 1/4</b>	Section number <b>6</b>	Township number <b>T 30 S</b>	Range number <b>R 37 E</b>
2. Distance and direction from nearest town or city: <b>From standard service station at Ulysses, Ks. 7 miles south, 2 west</b> Street address of well location if in city: <b>1/4 south</b> City, state, zip code: <b>Ulysses, Ks. 67880</b>					
4. Locate with "X" in section below: 			Sketch map: 6. Bore hole dia. <b>27</b> in. Completion date <b>6/27/77</b> Well depth <b>469</b> ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Brown clay			9. Casing: Material <b>Steel</b> Height: <b>18</b> in. or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>18</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>46.8</b> lbs./ft. Dia. <b>16</b> in. to <b>249.3</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>219</b>		
			10. Screens: Manufacturer's name <b>Lakewood Pipe of Texas</b> Type <b>steel</b> Dia. <b>16"</b> Slot/gauze <b>3/16"</b> Length <b>159.9'</b> Set between <b>249.3</b> ft. and <b>329</b> ft. <b>389</b> ft. and <b>469</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/4 x 5/8"</b>		
			11. Static water level: <input type="checkbox"/> mo./day/yr. <b>190</b> ft. below land surface Date <b>6-25-77</b>		
			12. Pumping level below land surfaces: <b>435</b> ft. after <b>24</b> hrs. pumping <b>900</b> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>900</b> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <b>18</b> inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
			16. Nearest source of possible contamination: <b>field</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Houck Bros. Drlg. Co. 164</b> Business name License No. Address <b>Box 487, Ulysses, Ks.</b> Signed <b>M. Beard</b> Date <b>9-23-77</b> Authorized representative		
19. Remarks: <b>60 FEET Johnson Screen set between 329 &amp; 389'</b>					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5