


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-120-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Corrected

Please correct this well record in your files

1. Location of well:	County Grant County	Fraction NN 1/4 NW 1/4 NE 1/4	Section number 14	Township number T 30 S	Range number R 37 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	3. Owner of well: Dave Stout R.R. or street: Box 447 City, state, zip code: Cluskes, KS 67880				
4. Locate with "X" in section below: 	Sketch map: 6. Bore hole dia. 16 in. Completion date _____ Well depth 220 ft.				
5. Type and color of material			From	To	
7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored _____ <input checked="" type="checkbox"/> Reverse rotary			8. Use: _____ Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____		
9. Casing: Material Steel Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP _____ PVC _____ Weight 31.65 lbs./ft. Dia. 16 in. to 220 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. #100			10. Screen: Manufacturer's name Johnson Type Johnson Calc. Dia. 100-160 Slot/gauze 8-20 Mesh Length _____ Set between 220-250 ft. and _____ ft. 220-250 ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material _____		
11. Static water level: _____ mo./day/yr. _____ ft. below land surface Date _____			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____			14. Well head completion: Pitless adapter 1 ft. inches above grade		
15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement _____ Bentonite _____ <input checked="" type="checkbox"/> Concrete _____ Depth: From _____ ft. to 10 ft.			16. Nearest source of possible contamination: ft. _____ Direction N/A Type _____ Well disinfected upon completion? _____ Yes _____ No		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ _____ Jet _____ Reciprocating _____ _____ Centrifugal _____ Other _____			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Walter Wilson Business name _____ License No. _____ Address Box 1, Garden City, KS Signed _____ Date _____ Authorized representative		
18. Elevation: Topography: _____ Hill _____ Slope _____ Upland _____ Valley	19. Remarks: (Use a second sheet if needed)				


Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant County	Fraction NE 1/4 NE 1/4 E 1/4	Section number 14	Township number T 30 S R 37 E W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:		9 South of Wysses on Hwy 25, 1 1/2 East, 1/4 South		3. Owner of well: Dave Stout (KI) R.R. or street: Box 447 City, state, zip code: Wysses, KS 67880		
<input checked="" type="checkbox"/> Locate with "X" in section below:		Sketch map:		<input checked="" type="checkbox"/> Bore hole dia. 26 in. Completion date 7-30-78 Well depth 280 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft. Dia 16 in. to 280 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
				10. Screen: Manufacturer's name Johnson Type Johnson Galv. Dia 100-16" Slot/gauze 0-220 Plain length Set between 220-250 Screen ft. 250-280 Perf. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/2 to 5/8		
				<input checked="" type="checkbox"/> Static water level: 794 ft. below land surface Date 7-11-78 mg./day/yr.		
				<input checked="" type="checkbox"/> Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. Address Box A, Garden City, KS Signed [Signature] Date 7-31-78 Authorized representative			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

P.O. Box A

GARDEN CITY, KANSAS 67846

July 11, 1978

Dave Stout Feedlot
Grant County

Location: East $\frac{1}{4}$ 14-30-37 Approx. 600' South of No. 1

Static Water Level -194

Test #2

	1	Top Soil
1	155	Brown Clay
155	164	Fine to med. sand and gravel 10% Clay (loose)
164	190	Brown Clay
190	200	Fine to med. sand and gravel 10% Clay (loose)
200	236	Fine to med. sand and gravel (loose)
236	258	Fine to med. sand and gravel Streaks of coarse gravel 10% Clay (loose)
258	270	Brown Clay
270	275	Fine to med. sand and gravel 15% Clay (loose)
275	293	Brown Clay (tight)
293	305	Brown Sandy Clay
305	380	Brown Clay (tight)
380	415	Brown Clay with Streaks of Brown Rock (tight) (hard Streaks)
415	435	C Brown Gray and Yellow Clay with brown Rock (hard)
435	440	P Red Bed (hard)

T. D. 280