

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County: Grant		Fraction: SE 1/4 SE 1/4 SW 1/4		Section number: 21		Township number: T 30 S R 37 E/W		Range number: 37	
2. Distance and direction from nearest town or city: 11 miles south, 7/10 west of Ulysses, Kansas Street address of well location if in city:				3. Owner of well: Tom Joyce R.R. or street: 204 S. Sullivan City, state, zip code: Ulysses, Ks. 67880					
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile				6. Bore hole dia. 27 in. Completion date 10-29-76 Well depth 411 ft.					
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
5. Type and color of material				From		To			
Surface				0		2			
Very fine sand & clay breakers				2		19			
Brown sandy clay w/lime shale & fine sand				19		127			
Fine to medium sand w/clay breakers				127		136			
Brown & sandy clay w/very fine sand strips				136		241			
Medium to coarse sand w/clay breakers				241		272			
Sandy clay w/fine sand strips				272		286			
Medium to coarse sand w/clay breakers 39 ft.				286		329			
Sandy clay				329		338			
Very fine to coarse sand w/clay breakers 33 ft.				338		377			
Brown shale, sandrock & Dakota 5%				377		393			
Brown shale, sandrock & Dakota 20%				393		411			
(Use a second sheet if needed)									
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		10. Screen: Manufacturer's name Lakewood Pipe of Texas Type steel Dia. 16" Slot/gauze 3/16 Length 167.6' Set between 243.6 ft. and 411 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/8"					
				11. Static water level: _____ mo./day/yr. 171 ft. below land surface Date 10-28-76					
				12. Pumping level below land surfaces: 380 ft. after 16 hrs. pumping 900 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 900 g.p.m.					
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____					
				14. Well head completion: NA <input type="checkbox"/> Pitless adapter _____ Inches above grade					
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
				16. Nearest source of possible contamination: Field ft. _____ Direction _____ Type MHC Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>					
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drilling Co. 164 Business name License No. _____ Address Box 487, Ulysses, Ks. Signed M. Beard Date 11/16/76 Authorized representative					

30 370 21
T
R
Sec
1/4 SE SE SW
1/4 1/4 1/4