

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

<input checked="" type="checkbox"/> 1. Location of well:	County Grant	Fraction SW 1/4 Sw 1/4 SW 1/4	<input checked="" type="checkbox"/> Section number 28	Township number 30	Range number 37
<input checked="" type="checkbox"/> 2. Distance and direction from nearest town or city: of Ulysses four way wtop Street address of well location if in city:	12 miles south		3. Owner of well: R.R. or street: Harry Joyce City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			6. Bore hole dia. 9 1/4 in. Completion date _____ Well depth 315 ft. 5/12/78		
Fine to coarse sand w/loose strips lime shells and clay breakers			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Brown clay, sand and gravel strips			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine to medium sand			9. Casing: Material styrene Height (Above or below surface) 20 in. Dia. 5 in. to 285 ft. depth! Wall Thickness: inches or Dia. _____ in. to _____ ft. depth! Gauge No. 320		
Fine to coarse sand, small gravel & small clay breakers			10. Screen: Manufacturer's name _____ Type SunFlower styrene Dia. 5" Slot/gauze 1/16" Length 30 Set between 285 ft. and 315 ft. ft. and 1 1/4 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material _____		
Very fine to medium sand			11. Static water level: 75 ft. below land surface Date 5/12/78		
Fine to coarse sand w/clay breakers			12. Pumping level below land surfaces: 82 ft. after 6 hrs. pumping 25 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.		
Very fine to medium sand w/clay breakers			13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Fine to coarse sand & small gravel			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade		
(Use a second sheet if needed)			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
18. Elevation:			16. Nearest source of possible contamination: ft. _____ Direction _____ Type field Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
19. Remarks:			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business no. Box 487, Ulysses, Ks. License No. _____ Address _____ Signed M. Beard Date 5/12/78 Authorized representative		

30
37
28
5/12/78
1/4 1/4 1/4
Sec