


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Grant	Township name Sullivan	Fraction SE 1/4 NE 1/4 SW 1/4	Section number 8	Town number 30S	Range number 38W
Distance and direction from nearest town or city: 5 miles west 9 south-2 west-1/2 north-1/4 west				3 Owner of well: Dillard Thomason Address: RFD 2 Ulysses, Ks.		
Locate with "X" in section below: 		Sketch map:		4 Well depth: 452 ft. Date of completion 8-27-75 Well diameter 27 in.		
2 Type and color of material		From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface		0	2	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
Sandy clay		2	16	7 Casing: Material stl Height: above /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16" Weight 36.8 lbs./ft. 1 0 in. to 234 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Brown clay & lime shale Hard		16	104	8 Screen: Manufacturer Lakewood Type stl Dia. 16" Slot/gauze 3/16 Length 2" slot Set between 234 ft. and 452 ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material 1/4 x 5/8		
Medium to coarse sand w/clay breakers		104	151	9 Static water level: 102.6 ft. below land surface Date 8-4-75		
Brown gummy clay		151	216	10 Pumping level below land surfaces: 225 ft. after 577 hrs. pumping 1092 g.p.m. Estimated maximum yield 1092 g.p.m.		
Sandy clay w/fine to coarse sand strips 14ft.		216	276	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Medium to coarse sand w/clay breakers 24ft.		276	304	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 12 inches above grade		
Sandy clay w/lime shale		304	317	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
Medium to coarse sand w/clay breakers 12ft.		317	333	14 Nearest source of possible contamination: ft. 1/2 mile direction SW Type trailer house Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Sandy clay sand rock & yellow chalk loose 8 ft.		378	396	15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sandy clay sand rock & Dakota loose		396	408	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name License No. Address Box 487, Ulysses, Ks. Signed Date Authorized representative		
Cheyenne sandstone & sandrock 15ft.		408	426			
Brown sahle & sandrock & Dakota 15ft.		426	455			
(use a second sheet if needed)						
16 Remarks: elevation Mr. Thomason grouted his well Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						