


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant	Fraction NW 1/4 NE 1/4 SW 1/4	Section number 16	Township number T 30 S R 38	Range number EW
2. Distance and direction from nearest town or city: 3 1/4 S. of Ulysses Street address of well location if in city: on Hiway 25, 1 3/4 on south, 6 3/4 west, 1/4 north				3. Owner of well: Bob Hennigh R.R. or street: RFB 2 City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below: 				Sketch map:		
5. Type and color of material				6. Bore hole dia. 26 in. Completion date 1-10-77 Well depth 525 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above 2555 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 526 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
				10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/groove <input type="checkbox"/> Length 20 ft. Set between 290-330 ft. and 400-410 ft. Perf: 210-290 ft. and 330-400 ft. 410 ft. 525 Gravel pack? yes Size range of material 25" down		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 170 ft. below land surface Date 2-11-77		
				12. Pumping level below land surfaces: 260 ft. after 2 hrs. pumping 1160 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1200 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				17. Pump: Manufacturer's name Goodyear Not installed Model number 127 HP 200 Volts 1200 Length of drop pipe 360 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter-Wilson Drilling Co. 208 Business name License No. Address Box A Garden City, Ks. Signed Robert L. Wilson Date 2-11-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

BOB HENNIGH
GRANT COUNTY
2/11/77

Location: SW 16-20-38 750ft. north west of pivot

Static Water Level- 170'

Test #2

0	5	Top soil
5	24	Fine sand
24	67	Brown sandy clay
67	112	Brown clay
112	187	Fine to med. sand and gravel with tight streaks
187	244	Fine to med. sand and gravel
244	259	Brown clay
259	331	Fine to med. sand and gravel
331	395	Brown and yellow clay
395	415	Cheyenne sand
415	471	Brown yellow and gray clay
471	494	Sand stone 10% clay
494	545	Brown and yellow clay
545	560	Red Bed

T.D. 525