

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Grant</b>	Fraction <b>SE 1/4 SW 1/4 NE 1/4</b>	Section number <b>28</b>	Township number <b>T 30 S R 38</b>	<b>EW</b>				
2. Distance and direction from nearest town or city: <b>Hwy jct. 270 &amp; 160 at Ulysses, 5 miles west-12 south-1 west</b> <small>Street address of well location if in city:</small>			3. Owner of well: <b>Edward KEPLEY RFD</b> R.R. or street: City, state, zip code: <b>Ulysses, Ks. 67880</b>						
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W <table border="1" style="display: inline-table; vertical-align: middle;"><tr><td>NW</td><td>NE</td></tr><tr><td>SW</td><td>SE</td></tr></table> E S 1 Mile</div>			NW	NE	SW	SE	Sketch map: <div style="text-align: center;"></div>		
NW	NE								
SW	SE								
5. Type and color of material			From	To	6. Bore hole dia. <u>26</u> in. Completion date <u>10-26-79</u> Well depth <u>518</u> ft.				
Surface			0	2	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
Very fine sand & clay			2	45	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
Brown sandy clay w/fine shale			45	122	9. Casing: Material <u>steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>287.7</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>287.7</u> ft. depth gage No. <u>219</u>				
Fine to coarse sand w/clay breakers			122	190	10. Screen: Manufacturer's name <u>Lakewood Pipe of Texas</u> Type <u>steel</u> Dia. <u>16"</u> Slot/gauze <u>3/16"</u> Length <u>230.5'</u> Set between <u>287.7'</u> ft. and <u>518'</u> ft. ft. and <u>518'</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 x 5/8"</u>				
Brown clay w/very fine sandstone			190	282	11. Static water level: <u>174</u> ft. below land surface Date <u>9-15-79</u> mo./day/yr.				
Medium to coarse sadn w/clay breakers			282	324	12. Pumping level below land surfaces: <u>249'</u> after <u>33.1</u> hrs. pumping <u>1177</u> g.p.m. ft. after <u>      </u> hrs. pumping <u>      </u> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.				
Cemented sand			324	333	13. Water sample submitted: <u>      </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u>      </u>				
Medium & coarse sand w/clay breakers 56 ft.			333	399	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> Inches above grade				
Brown shale, sandrock and Dakota 40%			399	420	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.				
Brown shale, sandrock & Dakota strips 15%			420	473	16. Nearest source of possible contamination: ft. <u>      </u> Direction <u>      </u> Type <u>field</u> Well disinfected upon completion? <u>      </u> Yes <input checked="" type="checkbox"/> No				
Brown shale, sandrock and Dakota strips 45%			473	518	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>      </u> Model number <u>      </u> HP <u>      </u> Volts <u>      </u> Length of drop pipe <u>      </u> ft. capacity <u>      </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
(Use a second sheet if needed)									
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Houck Bros. Drlg. Co. 164</b> Business name <b>Box 487, Ulysses, Ks.</b> Address <u>      </u> License No. <u>      </u> Signed <u>M. Beard</u> Date <u>12-4-79</u> Authorized representative						
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley									

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

30 380 28 SEC 1/4 1/4 1/4