


1 LOCATION OF WATER WELL		Fraction	Section Number		Township Number		Range Number			
County: Grant		SE 1/4 SW 1/4 NW 1/4	28		T 30 S		R 38 EW			
Distance and direction from nearest town or city? 5 west, 11 south, 2 west, 1/2 south of Ulysses, Ks.				Street address of well if located within city?						
2 WATER WELL OWNER:		Wayne Lahey		Board of Agriculture, Division of Water Resources						
RR#, St. Address, Box #		Ulysses, Ks. 67880		Application Number: 33459						
City, State, ZIP Code										
3 DEPTH OF COMPLETED WELL		399 ft. Bore Hole Diameter 26 in. to 399 ft., and in. to ft.								
Well Water to be used as:		5 Public water supply 8 Air conditioning 11 Injection well								
1 Domestic 3 Feedlot		6 Oil field water supply 9 Dewatering 12 Other (Specify below)								
2 Irrigation 4 Industrial		7 Lawn and garden only 10 Observation well								
Well's static water level		146 ft. below land surface measured on July 25 day 1980 year								
Pump Test Data		Well water was 220 ft. after 24 hours pumping 1980 gpm								
Est. Yield 2000 gpm		Well water was ft. after hours pumping gpm								
4 TYPE OF BLANK CASING USED:		5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped								
1 Steel 3 RMP (SR)		6 Asbestos-Cement 9 Other (specify below) Welded X								
2 PVC 4 ABS		7 Fiberglass Threaded								
Blank casing dia		16 in. to 259.11 ft. Dia in. to ft. Dia in. to ft.								
Casing height above land surface		10 in., weight 36.86 lbs./ft. Wall thickness or gauge No. 219								
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC 10 Asbestos-cement								
1 Steel 3 Stainless steel		8 RMP (SR) 11 Other (specify)								
2 Brass 4 Galvanized steel		6 Concrete tile 9 ABS 12 None used (open hole)								
Screen or Perforation Openings Are:		5 Gauzed wrapped 8 Saw cut 11 None (open hole)								
1 Continuous slot 3 Mill slot		6 Wire wrapped 9 Drilled holes								
2 Louvered shutter 4 Key punched		7 Torch cut 10 Other (specify)								
Screen-Perforation Dia		16 in. to 399 ft. Dia in. to ft. Dia in. to ft.								
Screen-Perforated Intervals:		From 259.11 ft. to 399 ft. From ft. to ft. From ft. to ft.								
Gravel Pack Intervals:		From 10 ft. to 399 ft. From ft. to ft. From ft. to ft.								
5 GROUT MATERIAL:		1 Neat cement 2 Cement grout 3 Bentonite 4 Other								
Grouted Intervals: From		0 ft. to 10 ft. From ft. to ft. From ft. to ft.								
What is the nearest source of possible contamination:		10 Fuel storage 14 Abandoned water well								
1 Septic tank 4 Cess pool		7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well								
2 Sewer lines 5 Seepage pit		8 Feed yard 12 Insecticide storage 16 Other (specify below)								
3 Lateral lines 6 Pit privy		9 Livestock pens 13 Watertight sewer lines field								
Direction from well		How many feet ? Water Well Disinfected? Yes X No								
Was a chemical/bacteriological sample submitted to Department? Yes		No X If yes, date sample								
was submitted month day year		Pump Installed? Yes No X								
If Yes: Pump Manufacturer's name		Model No. HP Volts								
Depth of Pump Intake		ft. Pumps Capacity rated at gal./min.								
Type of pump:		1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other								
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION:		This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was								
completed on		July 25 day 1980 year								
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No.		164								
This Water Well Record was completed on		October 22 day 1980 year								
name of Houck Bros. Drlg. Co.		by (signature) Mable Beard								
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG								
		0 2		Surface						
		2 20		Clay & fine sand						
		20 105		Clay w/lime shells						
		105 180		Medium to coarse sand w/clay breakers						
		180 220		Sandy clay w/fine sand						
		220 240		Fine to coarse sand						
		240 270		Sandy clay w/fine sand						
		270 325		Medium to coarse sand w/small clay breakers						
		325 339		Gray clay						
		339 398		Coarse sand and gravel						
ELEVATION:		398 403		Yellow chalk						
Depth(s) Groundwater Encountered		1. 146 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)								
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.										