

1 LOCATION OF WATER WELL: <b>Sumner</b>	FRACTION <b>NE 1/4 SE 1/4 SE 1/4</b>	Section Number <b>5</b>	Township Number <b>T 30 S</b>	Range Number <b>R 4W E/W</b>
--	---	----------------------------	----------------------------------	---------------------------------

Distance and direction from nearest town or city street address of well if located within city?

**K-42 And Suppesville, 1/4 N., West side Suppesville, Kansas**

WATER WELL OWNER: <b>SUPPEVILLE GOLF COURSE</b>	Board of Agriculture, Division of Water Resource
RR#, ST. ADDRESS, BOX #: <b>R.R #1</b>	Application Number:
CITY, STATE, ZIP CODE: <b>Suppesville, Kansas</b>	

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 	4 DEPTH OF COMPLETED WELL <b>60</b> ft. ELEVATION:
	Depth(s) groundwater Encountered <b>1</b> ft. <b>2</b> ft. <b>3</b> ft.
	WELL'S STATIC WATER LEVEL <b>10</b> FT. BELOW LAND SURFACE MEASURED ON <b>09/14/1998</b>
	Pump test data: Well water was <b>ft.</b> after <b>hours</b> pumping <b>gpm</b>
	Est. Yield <b>gpm</b> : Well water was <b>ft.</b> after <b>hours</b> pumping <b>gpm</b>
Bore Hole Diameter <b>12</b> in. to <b>60</b> ft. and in. to ft.	
WELL WATER TO BE USED AS:	
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)	
2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well	
Was a chemical/bacteriological sample submitted to Department? Yes	No <b>X</b> ; If yes, mo/day/yr sample was submitted
Water Well Disinfected? Yes <b>X</b> No	

5 TYPE OF CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued <b>X</b> Clamped
1 Steel 3 RMP (SR)	6 Asbestos-Cement	9 Other (Specify below)	Welded
2 PVC 4 ABS	7 Fiberglass	<b>SDR-26</b>	Threaded
Blank casing Diameter <b>5</b> in. to <b>24</b> ft., Dia	in. to ft., Dia	in. to ft.	
Casing height above land surface <b>12</b> in., weight <b>2.35</b> lbs. / ft.	Wall thickness or gauge No. <b>.214</b>		
TYPE OF SCREEN OR PERFORATION MATERIAL:	7 PVC	10 Asbestos-cement	
1 Steel 3 Stainless Steel 5 Fiberglass 8 RMP (SR) 11 other (specify)			
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)			
SCREEN OR PERFORATION OPENING ARE:	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes			
2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)			
SCREEN-PERFORATION INTERVALS: from <b>24</b> ft. to <b>60</b> ft., From ft. to ft.			
GRAVEL PACK INTERVALS: from <b>20</b> ft. to <b>60</b> ft., From ft. to ft.			

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other <b>bentonite hole plug</b>
Grout Intervals: From <b>4</b> ft. to <b>24</b> ft. From ft. to ft.
What is the nearest source of possible contamination:
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandon water well
2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well
3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)
13 Insecticide storage <b>None Apparent</b>

Direction from well?		How many feet?	
FROM	TO	LITHOLOGIC LOG	PLUGGING INTERVALS
0	2	topsoil	
2	10	fine sand	
10	18	clay	
18	32	fine sand	
32	60	shale	

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <b>09/14/1998</b> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <b>236</b> This Water Well Record was completed on (mo/day/yr) <b>09/16/98</b> Under the business name of <b>Harp Well &amp; Pump Service, Inc.</b> by (signature)
--

*Todd S. Harp*