

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sumner	Fraction 1/4 SW 1/4 SW 1/4	Section number 4	Township number T. 30 S R 4 NW	Range number 4 NW
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Haynes & Hecox Co. R.R. or street: 3202 West 13th Street City, state, zip code: Wichita, Kansas 67203		
4. Locate with "X" in section below: N Sketch map: less than 1/2 North of 42 Highway			6. Bore hole dia. 1 1/2 in. Completion date 11-22-76 Well depth 65 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material styrene Height: Above or below/ Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 65 ft. depth Wall Thickness: inches or Dia. 5 in. to 65 ft. depth gage No. 200		
			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gage .06 Length 40' Set between 25 ft. and 65 ft. Gravel pack? yes Size range of material 1/4-1/8"		
			11. Static water level: 20 ft. below land surface Date 11-22-76 mo./day/yr.		
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
			13. Water sample submitted: ____ mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date ____		
			14. Well head completion: well seal Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 6 ft. to 16 ft.		
			16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name Sta-Rite Model number 20P4D02 HP 3/4 Volts 230 Length of drop pipe 45 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation: Topography: ____ Hill ____ Slope ____ Upland ____ Valley	19. Remarks: Septic Tank not installed when the well was drilled No apparent source for contamination. Well to be inside building.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. ____ Address ____ Signed M. Arnold Date 12-2-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5