

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Sumner</b>	Fraction <b>1/4 SW 1/4 SW 1/4</b>	Section number <b>4</b>	Township number <b>30</b>	Range number <b>4</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:		<b>1/4 mile East of Suppesville, Kansas and 1/2 North of the 42 Highway</b>				
4. Locate with "X" in section below:		Sketch map: 				
5. Type and color of material		From	To	6. Bore hole dia. <b>11</b> in. Completion date <b>11-22-76</b> Well depth <b>75</b> ft.		
Sandy Topsoil		0	2	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Fine Sand		2	14	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Gray Clay		14	22	9. Casing: Material <b>styrene</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <b>5</b> in. to <b>75</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <b>200</b>		
Fine Sand		22	29	10. Screen: Manufacturer's name <b>Sunflower Plastic</b> Type <b>styrene</b> Dia. <b>5"</b> Slot/gauge <b>.06</b> Length <b>30'</b> Set between <b>37</b> ft. and <b>75</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/4-1/8"</b>		
Red Shale		29	37	11. Static water level: <b>20</b> ft. below land surface Date <b>11-22-</b> 12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Gray Shale		37	39	13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____		
Red Shale		39	75	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <b>12</b> inches above grade 15. Well grouted? <input checked="" type="checkbox"/> Yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>40'</b> to <b>14'</b> ft.		
				16. Nearest source of possible contamination: <b>NONE</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
				17. Pump: _____ Not installed Manufacturer's name <b>Sta-Rite</b> Model number <b>20P4D02</b> HP <b>3/4</b> Volts <b>230</b> Length of drop pipe <b>55</b> ft. capacity <b>20</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other _____		
18. Elevation:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Harp Well &amp; Pump 236</b> Business name <b>Wichita, Kansas</b> License No. _____ Address _____ Signed <b>M. Arnold</b> Date <b>12-10-76</b> Authorized representative		
19. Remarks:						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						
Septic Tank not installed when the well was drilled.  No apparent source for contamination.						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5