

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sumner	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 5	Township number T 30 S R 4 W	Range number 4
2. Distance and direction from nearest town or city: West edge of Suppesville Street address of well location if in city:				3. Owner of well: Kansas Dept. of transportation R.R. or street: State Office Building City, state, zip code: Topeka, Kansas 66612		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map: <i>Township Rd.</i> <i>428'</i> <i>164'</i> <i>K42(E)</i>		
5. Type and color of material				From	To	6. Bore hole dia. 12 in. Completion date 3-26-82 Well depth 57 ft.
Clay and sand, brown to reddish-brown				0	12.0	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay, very sandy, reddish-brown				12.0	17.5	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sand, fine to med., slightly clayey. Lt. brown				17.5	29.0	9. Casing: Material <input type="checkbox"/> Height: Above or <input checked="" type="checkbox"/> Below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 1.25 Ft. K RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3,584 lbs./ft. Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.280
Sand, fine to med., few coarse grains, clean				29.0	35.0	10. Screen: Manufacturer's name Pumpco Regular Slotted, Sch. 40 Type PVC Dia. 6" ID Slot/gauze <input type="checkbox"/> Length 18.0 Ft. Set between 33.0 ft. and 51.0 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/8-3/4
Sand with numerous lt. gray and lt. pink cl. Z				35.0	37.6	11. Static water level: <input type="checkbox"/> mo./day/yr. 27.6 ft. below land surface Date 3-26-82
Sand, fine to coarse, clean				37.6	51.6	12. Pumping level below land surfaces: 46.5 ft. after 8 hrs. pumping 33 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 38 g.p.m.
Shale, maroon (Ninnescah Shale Member)				51.6	57.0	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date Apr. 1982
						14. Well head completion: Hand Pump <input type="checkbox"/> Pitless adapter 1.25 Ft. inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 24 ft.
						16. Nearest source of possible contamination: ft. 250 Direction W. Type outhouse Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Handpump Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 40 ft. capacity 2 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation: 1166.0 Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kansas Dept. of Transportation Business name Topeka, Kansas License No. 3/29/82 Address Topeka, Kansas Signed <i>[Signature]</i> Date 3/29/82 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5