


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Stanton	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 23	Township number T 30 S R 41	Range number 41
2. Distance and direction from nearest town or city: from hiway ject. at Johnson, Ks. 10 7/10 miles south, 2/10 of a mile west, 2/10 of a mile north			3. Owner of well: Julius Johns Johnson, Ks. 67855		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>245</u> ft. <u>10/19/79</u>		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Brown clay			9. Casing: Material <u>steel</u> Height <u>Above</u> or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP _____ PVC _____ Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>204.9</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>219</u>		
Brown sandy clay w/fine sand strips			10. Screen: Manufacturer's name _____ Johnson Screen Type <u>steel</u> Dia. <u>16"</u> Slot/gauze <u>.100</u> Length <u>40.3'</u> Set between <u>204.9</u> ft. and <u>245</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 x 5/8"</u>		
Medium to coarse sand w/clay breakers			11. Static water level: <u>189</u> ft. below land surface Date <u>10/19/79</u> ^{mo./day/yr.}		
Sandy clay			12. Pumping level below land surfaces: <u>223</u> ft. after <u>36</u> hrs. pumping <u>1000</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ <u>1100</u> g.p.m.		
Medium to coarse sand, sandrock W/ cemented strips of clay breakers			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Blue shale			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> Inches above grade		
Blue shale, sandrock, false red bed & Dakota (tight)			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: ft. _____ Direction _____ Type <u>field</u> Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Houck Bros. Drlg. Co.</u> <u>164</u> Business name License No. Address <u>Box 487, Ulysses, Ks.</u> Signed <u>M. Beane</u> <u>12/4/79</u> Authorized representative Date			

30
41
23
WUSESE
1/4 1/4 1/4