

WATER WELL RECORD Form WWC-5

Division of Water Resources App. No.


Well ID

Original Record Correction Change in Well Use

1 LOCATION OF WATER WELL: County: Stanton Fraction NW 1/4 NW 1/4 SW 1/4 SW 1/4 Section Number 3 Township Number T 30 S Range Number R 42 E W

2 WELL OWNER: Last Name: Banuelos First: Octavio Street or Rural Address where well is located (if unknown, distance and direction from nearest town or intersection): Hwy 160 South Manter Grade. 3.85 Miles South and then 1 Mile West.

3 LOCATE WELL WITH "X" IN SECTION BOX: N W E S



4 DEPTH OF COMPLETED WELL: 420 ft. Depth(s) Groundwater Encountered: 1) 185 ft. 2) ... ft. 3) ... ft., or 4) Dry Well WELL'S STATIC WATER LEVEL: 185 ft. below land surface, measured on (mo-day-yr) 09/12/2018

5 Latitude: 37.464799 (decimal degrees) Longitude: 101.907602 (decimal degrees) Datum: WGS 84 NAD 83 NAD 27 Source for Latitude/Longitude: GPS (unit make/model) (WAAS enabled? Yes No) Land Survey Topographic Map Online Mapper

6 Elevation: 3493 ft. Ground Level TOC Source: Land Survey GPS Topographic Map Other KOLAR

7 WELL WATER TO BE USED AS: 1. Domestic: Household Lawn & Garden Livestock Irrigation Feedlot Industrial 5. Public Water Supply: well ID 6. Dewatering: how many wells? 7. Aquifer Recharge: well ID 8. Monitoring: well ID 9. Environmental Remediation: well ID Air Sparge Soil Vapor Extraction Recovery Injection 10. Oil Field Water Supply: lease 11. Test Hole: well ID Cased Uncased Geotechnical 12. Geothermal: how many bores? a) Closed Loop Horizontal Vertical b) Open Loop Surface Discharge Inj. of Water 13. Other (specify):

Was a chemical/bacteriological sample submitted to KDHE? Yes No If yes, date sample was submitted: Water well disinfected? Yes No

8 TYPE OF CASING USED: Steel PVC Other CASING JOINTS: Glued Clamped Welded Threaded Casing diameter 6 in. to 420 ft., Diameter in. to ft., Diameter in. to ft. Casing height above land surface 24 in. Weight lbs./ft. Wall thickness or gauge No. SDR 17

TYPE OF SCREEN OR PERFORATION MATERIAL: Steel Stainless Steel Fiberglass PVC Other (Specify) Brass Galvanized Steel Concrete tile None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: Continuous Slot Mill Slot Gauze Wrapped Torch Cut Drilled Holes Other (Specify) Louvered Shutter Key Punched Wire Wrapped Saw Cut None (Open Hole) SCREEN-PERFORATED INTERVALS: From 300 ft. to 420 ft., From ft. to ft., From ft. to ft. GRAVEL PACK INTERVALS: From 0 ft. to 5 ft., From 30 ft. to 420 ft., From ft. to ft.

9 GROUT MATERIAL: Neat cement Cement grout Bentonite Other Grout Intervals: From 5 ft. to 30 ft., From ft. to ft., From ft. to ft., From ft. to ft.

Nearest source of possible contamination: Septic Tank Lateral Lines Pit Privy Livestock Pens Insecticide Storage Sewer Lines Cess Pool Sewage Lagoon Fuel Storage Abandoned Water Well Watertight Sewer Lines Seepage Pit Feedyard Fertilizer Storage Oil Well/Gas Well Other (Specify) Direction from well? East Distance from well? 40 ft.

Table with 6 columns: FROM, TO, LITHOLOGIC LOG, FROM, TO, LITHO. LOG (cont.) or PLUGGING INTERVALS. Includes a 'Notes' section.

11 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, reconstructed, or plugged under my jurisdiction and was completed on (mo-day-year) 09/12/2018 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 846 This Water Well Record was completed on (mo-day-year) 09/19/2018 under the business name of Nash Water Well Service, LLC

Form	WWC5
Contractor	Nash Water Well Service, LLC
Well Owner	Octavio Banuelos
Doc ID	1422333

Litholgy

0	30	TOP SOIL, FINE COARSE SAND WITH CALICHE TAN CLAY
30	80	TAN/BROWN CLAY WITH FINE COARSE SAND STREAKS AND LAYERS
80	108	FINE COARSE SAND WITH SMALL/MEDIUM/LARGE GRAVEL
108	118	TAN/YELLOW CLAY
118	145	TAN SANDSTONE
145	160	TAN/GRAY/YELLOW CLAY WITH FINE SAND STREAKS AND THIN ROCK STREAKS
160	190	TAN SANDSTONE
190	200	FINE MEDIUM SAND
200	208	GRAY/TAN CLAY WITH FINE SAND STREAKS AND ROCK THIN LAYERS
208	270	BLUE SHALE AND BLUE CLAY
270	280	TAN/GRAY CLAY AND GRAY SANDSTONE
280	338	TAN SANDSTONE
338	345	RED CLAY WITH SANDSTONE

Form	WWC5
Contractor	Nash Water Well Service, LLC
Well Owner	Octavio Banuelos
Doc ID	1422333

Litholgy

		AND ROCK LAYERS
345	350	RED SANDSTONE
350	355	TAN SANDSTONE WITH ROCK LAYERS
355	360	RED PEBBLE CLAY
360	410	TAN SANDSTONE
410	420	RED/GRAY/PURPLE SHALE