

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

Location of well: County **Stanton** Fraction **NW 1/4 NE 1/4 NE 1/4** Section number **28** Township number **T 30 S R** Range number **43 E/W**

Distance and direction from nearest town or city: **5 south of Saunders** 3. Owner of well: **LaVere Walker**  
Street address of well location if in city: **Kansas** R.R. or street: **Johnson, Kansas 67855**  
City, state, zip code:

4. Locate with "X" in section below: Sketch map:

1 Mile W 1 Mile S

6. Bore hole dia. 9 1/2 in. Completion date Aug. 5, 1976  
Well depth 155 ft.

7.  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material styrene Height 12 Above or below  
Threaded  Welded gl Surface 12 in.  
RMP  PVC  Weight          lbs./ft.  
Dia. 5 in. to 115 ft. depth Wall Thickness: inches or  
Dia.          in. to          ft. depth Gage No. 320

5. Type and color of material	From	To
Surface	0	2
Sandy clay	2	55
Medium to coarse sand	55	90
Coarse sand & gravael	90	155

10. Screen: Manufacturer's name Sunflower  
Type styrene Dia. 5"  
Slot/gauze 1/16 Length 40  
Set between 115 ft. and 155 ft.  
         ft. and          ft.  
Gravel pack?  Size range of material No. 1

11. Static water level: 120 ft. below land surface Date 6-25-76

12. Pumping level below land surfaces:  
125 ft. after 12 hrs. pumping 12 g.p.m.  
         ft. after          hrs. pumping          g.p.m.  
Estimated maximum yield 12 g.p.m.

13. Water sample submitted:          mo./day/yr.  
Yes  No  Date         

14. Well head completion:  
 Pitless adapter 10 inches above grade

15. Well grouted?   
With:          Neat cement  Bentonite          Concrete  
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:  
ft. 250 Direction south Type septic tank  
Well disinfected upon completion?  Yes  No

17. Pump:  Not installed  
Manufacturer's name           
Model number          HP          Volts           
Length of drop pipe          ft. capacity          g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

(Use a second sheet if needed)

18. Elevation: Topography:  
 Hill  
 Slope  
 Upland  
 Valley

19. Remarks:

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Houck Bros. Drilling Co. 164  
Business name License No.  
Address Box 487, Ilysses, Ks.  
Signed Mellie M. Beard Date 10/15/76  
Authorized representative

30 - 430W - 28 - 1/4 1/4 NW NE NE