


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County KINGMAN		Fraction 1/4 NW 1/4 SW 1/4	Section number 13	Township number 30 S	Range number 5W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 3 West of Suppesville and 1/2 North of K-42 Hyway			3. Owner of well: L & M Enterprises and Darryl Elliott City, state, zip code: Conway Springs, Kansas		
4. Locate with "X" in section below: N 1/4 East. Norwich, Kansas Sketch map: 			6. Bore hole dia. 11 in. Completion date 3-16-78 Well depth 55 ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material styrene Height: Above of below 1111 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1111 lbs./ft. Dia. 5 in. to 55 ft. depth Wall Thickness: inches 200 Dia. 5 in. to 55 ft. depth gage No. 200		
			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot 1/16 in. Length 30' Set between 25 ft. and 55 ft. ft. and 55 ft. Gravel pack? yes Size range of material 1/4-1/8"		
			11. Static water level: 15 ft. below land surface Date 3-16-78		
(Use a second sheet if needed)			12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
			13. Water sample submitted: mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes 1-2 fine sand mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4'0" ft. to 14 ft.		
			16. Nearest source of possible contamination: Septic Tank ft. 65 Direction East Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17. Pump: Manufacturer's name Sta-Rite Not installed Model number 20 P4D02 HP 3/4 Volts 230 Length of drop pipe 30 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. Address Wichita, Kansas Signed M. Arnold Date 4-17-78 Authorized representative		
			19. Remarks: Flat Ground		