

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kingman	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 33	Township number T 30 S R 6W E/W	Range number
2. Distance and direction from nearest town or city: 7 West and 4 1/2 South of, Street address of well location if in city: Norwick, Kansas				3. Owner of well: Lee Vangieson R.R. or street: Rago, Kansas City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 11 in. Completion date 3-24-77 Well depth 125 ft.		
5. Type and color of material		From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material Styrene Height: Above <input checked="" type="checkbox"/> Below <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 125 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 200
						10. Screen: Manufacturer's name Sunflower Plastic Type Styrene Dia. 5" Slot/Bar .06 Length 90' Set between 35 ft. and 125 ft. Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft.
						Gravel pack? yes Size range of material 1/4-1/8"
11. Static water level: 18 ft. below land surface Date 3-24-77 mp./day/yr.		12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date ____		
14. Well head completion: capped <input type="checkbox"/> Pitless adapter 12 Inches above grade		15. Well grouted? yes OK 1/1 sand mix With: <input type="checkbox"/> Nept cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.		16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		18. Elevation:		19. Remarks: No apparent source of, contamination. Well in field.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 4-6-77 Authorized representative