

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kingman	Fraction Center on North Side of 1/4 1/4 SW 1/4	Section number 20	Township number T 30 S R 8	Range number 8
2. Distance and direction from nearest town or city: 4 miles Southwest of Spivey, KS Street address of well location if in city:			3. Owner of well: W. D. Carrick R.R. or street: Route 1 City, state, zip code: Spivey, KS 67142			
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div> Sketch map:			6. Bore hole dia. 24 in. Completion date 7-13-78 Well depth 75 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <u>steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>30.3</u> lbs./ft. Dia. <u>16</u> in. to <u>55</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>7 ga.</u>			
			10. Screen: Manufacturer's name <u>W. A. Brown</u> Type <u>Double-slot</u> Dia. <u>16"</u> Slot gauze <u>1/8"</u> Length <u>20'</u> Set between <u>55'</u> ft. and <u>75'</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>3/8-200</u>			
			11. Static water level: <u>N/C</u> mo./day/yr. <u>N/C</u> ft. below land surface Date <u> </u>			
(Use a second sheet if needed)			12. Pumping level below land surfaces: <u>N/C</u> <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.			
			13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <input checked="" type="checkbox"/> No <u> </u> Date <u> </u>			
			14. Well head completion: <u> </u> Pitless adapter <u>12</u> Inches above grade			
			15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
			16. Nearest source of possible contamination: <u>FIELD</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u> </u> Yes <input checked="" type="checkbox"/> No			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17. Pump: <u>Not installed</u> Manufacturer's name <u>Berkeley Pump Co.</u> Model number <u>1001M-7</u> HP <u>60</u> Volts <u> </u> Length of drop pipe <u>60</u> ft. capacity <u>300</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. <u>67530</u> Address <u>Great Bend, KS</u> Signed <u>DW Carrick</u> Date <u>2/7/79</u> Authorized representative			
			19. Remarks:			
			19. Remarks:			
			19. Remarks:			

30
- 80
20
CN SW
1/4 1/4 1/4