

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Barber</b>	Fraction <b>SE 1/4 SW 1/4 NE 1/4</b>	Section number <b>3</b>	Township number <b>T 31 S R 10W</b>	Range number <b>E 10W</b>
2. Distance and direction from nearest town or city: <b>5S 1 3/4 E 1/2 N</b> Street address of well location if in city: <b>Nashville, Kansas</b>			3. Owner of well: <b>Kent Lawrence</b> R.R. or street: City, state, zip code: <b>Nashville, Kansas</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date _____ Well depth <u>157</u> ft. <u>15 July 76</u>		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Soil		0	2	9. Casing: Material <u>Stl</u> Height: <u>Above</u> or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP _____ PVC _____ Weight <u>31.7</u> lbs./ft. Dia. <u>16</u> in. to <u>106</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. <u>188</u>		
Sand, silty		2	23	10. Screen: Manufacturer's name <u>W.A. Brown And Cook</u> Type <u>Freeflo</u> Dia. <u>16</u> " Slot gauge <u>1/8</u> " Length <u>50</u> ' Set between <u>106</u> ft. and <u>126</u> ft. <u>Freeflo</u> <u>126-136 Cook</u> and <u>136-156 Freeflo</u> Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>2x1/8</u>		
Sand, fine to coarse		23	59	11. Static water level: _____ mo./day/yr. <u>66</u> ft. below land surface Date <u>15 July 76</u>		
Clay, tan Hard		59	74	12. Pumping level below land surfaces: <u>92</u> ft. after <u>1</u> hrs. pumping <u>556</u> g.p.m. <u>103</u> ft. after <u>1</u> hrs. pumping <u>708</u> g.p.m. Estimated maximum yield <u>900</u> g.p.m.		
Sand, fine to coarse		74	107	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Clay, tan Hard		107	110	14. Well head completion: <input checked="" type="checkbox"/> Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
Sand, fine to coarse and medium gravel		110	136	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Clay, tan Hard		136	140	16. Nearest source of possible contamination: <u>Farm</u> ft. <u>2600</u> Direction <u>NW</u> Type <u>Stead</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sand, fine to coarse		140	156	17. Pump: _____ Not installed Manufacturer's name <u>Floway</u> Model number <u>10Dol</u> HP <u>60</u> Volts _____ Length of drop pipe <u>120</u> ' ft. capacity <u>500</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Shale, red		156	158	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Central Well &amp; Pump 325</u> Business name _____ License No. _____ Address <u>121 S. Taylor</u> Signed <u>John Romill</u> Date <u>19 July 76</u> Authorized representative		
18. Elevation:		(Use a second sheet if needed)		21. 17 1/4		
19. Remarks: A 5'x12'x1' concrete pump and engine base was poured at surface.				22. 3		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				23. 1/4 SE SW NE		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5