


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Barber	Fraction NE NE SW 1/4 NE 1/4 1/4	Section number 8	Township number T 31 S R	Range number 10
2. Distance and direction from nearest town or city: 6.6 N NW of Sharon, Kansas			3. Owner of well: Geo. E. Carter Trust & Roger Johnson R.R. or street: City, state, zip code: Hutchinson, Kansas 67501			
4. Locate with "X" in section below: 			Sketch map:			6. Bore hole dia. 10 in. Completion date 5-16-81 Well depth 135 ft.
5. Type and color of material			From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
earth			0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
brown clay			3	8	9. Casing: Material plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 160 lbs./ft. Dia. 5 in. to 135 ft. depth Wall Thickness: inches or Dia. 5 in. to 135 ft. depth gage No. SDR 26	
fine dry sand-brown			8	32	10. Screens: Manufacturer's name Jet Stream SDR 26 Type PVC Dia. 5" Slot/gauze 1/16 Length 10" Set between 124 ft. and 134 ft. ft. and _____ ft. Gravel pack? yes Range of material 1/16x3/8	
coarse dry sand-brown			32	45	11. Static water level: _____ mo./day/yr. 79 ft. below land surface Date 5-16-81	
real sandy brown clay			45	60	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ 60 g.p.m.	
brown fine sand			60	75	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
yellow clay			75	88	14. Well head completion: well seal <input type="checkbox"/> Pitless adapter 18 Inches above grade	
fine brown sand			88	99	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neg. cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 12 ft.	
fine brown sand clay balls			99	121	16. Nearest source of possible contamination: ft. 1000 Direction SE Type pond Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
brown coarse sand			121	134	17. Pump: windmill Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe 94 ft. capacity 15 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
clay			134	135	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hank Bruse Water Well Serv Business name _____ License No. _____ Address 1117 Stout 103 Signed Hank Bruse Date _____ Authorized Representative	
18. Elevation:			19. Remarks:			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			(Use a second sheet if needed)			

31-10-81
T
R
Sec
1/4 1/4 1/4