

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <b>Commanche</b> Fraction <b>SW 1/4 SW 1/4 SE 1/4</b> Section number <b>2</b> Township number <b>T 31 S R 17 W</b> Range number	
2. Distance and direction from nearest town or city: <b>2 N 4 E Wilmore Kansas</b> Street address of well location if in city.	
3. Owner of well: <b>Lester Nielsen</b> R.R. or street: City, state, zip code: <b>Wilmore Kansas</b>	
4. Locate with "X" in section below: Sketch map:	
5. Type and color of material	
	From To
Top Soil	0 2
Gray Clay	2 22
BR. Clay with Gyp	22 66
Gray Sandy Clay	66 75
BR. Clay	75 89
Gray Clay	89 96
Gravel Fine To 1/4	96 100
6. Bore hole dia. <b>8 3/4</b> in. Completion date <b>5-7-75</b> Well depth <b>110</b> ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <b>PI</b> Height: Above or below <b>8 1/2</b> in. Threading: <b>Welded</b> Surface: <b>PI</b> RMP: <b>X</b> PVC: <input type="checkbox"/> Weight: <b>8 1/2</b> lbs./ft. Dia. <b>5</b> in. to <b>110</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <b>200</b>	
10. Screen: Manufacturer's name <b>SunFlower Plastic</b> Type <b>RMP</b> Dia. <b>5"</b> Slot/auze <b>1/8</b> Length <b>20</b> Set between <b>90</b> ft. and <b>110</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/4 X 1/2</b>	
11. Static water level: <b>58</b> ft. below land surface Date <b>5-7-75</b> mo./day/yr.	
12. Pumping level below land surfaces: <b>58</b> ft. after <b>1</b> hrs. pumping <b>3</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>10</b> g.p.m.	
13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date	
14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade	
15. Well grouted? <b>YES</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
16. Nearest source of possible contamination: <b>BARN</b> ft. <b>50</b> Direction <b>N.</b> Type <b>BARN</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>W Adams</b> Model number <b>HP 11</b> Volts <input type="checkbox"/> Length of drop pipe <b>84</b> ft. capacity <b>3</b> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation:	19. Remarks:
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>CARL HAYSE WATER WELL SERVICE</b> Business name <b>603 S. Maple, Greensburg, Kans.</b> License No. <b>224</b> Signed <b>Carl Hayse</b> Date <b>5-7-75</b> Authorized representative	

T 31 S R 17 W Sec 2 SW SW SE 1/4 1/4 1/4