

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Commanche	Fraction NE 1/4 NW 1/4 SW 1/4	Section number 18	Township number T 31 (5) R	Range number 18 (W)
2. Distance and direction from nearest town or city: 4 1/2 mile N of Coldwater, Kansas			3. Owner of well: Jack Vance			
Street address of well location if in city:			R.R. or street: City, state, zip code: Coldwater, Ks			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 1/2 in. Completion date 5/16/81 Well depth 120 ft.		
N				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
W				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
E		S 1 Mile		9. Casing: Material PVC Height (Above) or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 160 Wall		
1 Mile				10. Screen: Manufacturer's name _____ Type _____ Dia. _____ <input checked="" type="checkbox"/> 10 gauge 1/16 Length 20 Set between 95 ft. and 115 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 4g + 3/8		
5. Type and color of material				From	To	11. Static water level: _____ mo./day/yr. _____ ft. below land surface Date _____
Sandy loam				0	5	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.
Sand + Clay				5	20	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Clay w/ layers of gravel				20	95	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade
Gravel w/ layers of clay				95		15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. 2500 Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: Water pump <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Lehl & Son 141 Business name License No. Address 132 E Okla Ave Okla Signed Carl Jell Date _____ Authorized representative
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						31 18 W 18 1/4 1/4 1/4 1/4 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5