

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County COMANCHE	Fraction NE 1/4 SW 1/4 SW 1/4	Section number 21	Township number T 31 S R 18 W E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Betty Jean Proctor R.R. or street: City, state, zip code: Alva, Okla			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date _____ Well depth 310 ft. 31 Dec 77		
				7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____		
Silt, sandy		0	2	9. Casing: Material SH Height Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia 16 in. to 190 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 188		
Sand, fine to coarse with tan and white clay stks		2	87	10. Screen: Manufacturer's name _____ Truflow Type _____ Dia. 16" Slot/gauze 1/8 Length 120' Set between 190 ft. and 310 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/2		
Sand, fine to coarse and fine to coarse gravel		87	105	11. Static water level: _____ mo./day/yr. 106 ft. below land surface Date 31 Dec 77		
Clay, white and tan		105	142	12. Pumping level below land surfaces: 145 ft. after 1 1/2 hrs. pumping 800 g.p.m. 161 ft. after 1 hrs. pumping 1200 g.p.m. Estimated maximum yield 1600 g.p.m.		
Sand, fine to coarse and fine to med. gravel		142	164	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
Clay, tan		164	185	14. Well head completion: _____ Pitless adapter 12 Inches above grade		
Sand, very fine to med.		185	196	15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.		
Sand, very fine to coarse and fine to med. gravel		196	205	16. Nearest source of possible contamination: ft. _____ Direction _____ Type None Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
Sand, very fine to coarse and fine to coarse gravel		205	211	17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP 80 Volts _____ Length of drop pipe 220 ft. capacity 800 g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
Clay, red, sandy		211	248	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump Svc. 325 Business name _____ License No. _____ Address 121 S. Taylor Pratt, Ks. Signed L. Hononick Date 24 Dec 78 Authorized representative		
Sand, fine to coarse and fine to coarse gravel		248	250			
Sand, fine to coarse and fine to coarse gravel		250	265			
Clay, tan, sandy		265	268			
Sand, very fine to coarse with some clay streaks		268	300			
Sand, very fine to med. with some clay streaks		300	310			
Shale (Use a second sheet if needed)		310	315			
18. Elevation:		19. Remarks:				
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley		6' X 12' X 8" slab poured at surface				

3
1
1
1
8
2
1
1/4
1/4
1/4
NE
SW
SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5