


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Comanche	Township name	Fraction SW 1/4	Section number 29	Town number 31 S	Range number 18 W																																															
Distance and direction from nearest town or city: 2 Miles North of Coldwater, Ks.			3 Owner of well: Roy Boisseau Address: Coldwater, Kansas																																																		
Street address of well location if in city:			Address:																																																		
Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			4 Well depth: 295 ft. Date of completion 2/75 Well diameter 30 in.																																															
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:50%;">2 Type and color of material</th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr><td>Top soil</td><td>0</td><td>2</td></tr> <tr><td>Brown silty sand</td><td>2</td><td>26</td></tr> <tr><td>Brown clay</td><td>26</td><td>31</td></tr> <tr><td>Med. to coarse sand & gravel</td><td>31</td><td>76</td></tr> <tr><td>Brown clay</td><td>76</td><td>94</td></tr> <tr><td>Med. to coarse sand & gravel</td><td>94</td><td>105</td></tr> <tr><td>Brown clay</td><td>105</td><td>121</td></tr> <tr><td>Med. to coarse sand to med. gravel</td><td>121</td><td>131</td></tr> <tr><td>Brown clay</td><td>131</td><td>137</td></tr> <tr><td>Med. to coarse sand to med. gravel</td><td>137</td><td>160</td></tr> <tr><td>Brown clay</td><td>160</td><td>185</td></tr> <tr><td>Med. to coarse sand to med. gravel w/ clay lenses</td><td>185</td><td>221</td></tr> <tr><td>Med. to coarse sand to med. gravel</td><td>221</td><td>277</td></tr> <tr><td>Gray clay</td><td>277</td><td>284</td></tr> <tr><td>Med. to coarse sand & gravel</td><td>284</td><td>294</td></tr> </tbody> </table>			2 Type and color of material	From	To	Top soil	0	2	Brown silty sand	2	26	Brown clay	26	31	Med. to coarse sand & gravel	31	76	Brown clay	76	94	Med. to coarse sand & gravel	94	105	Brown clay	105	121	Med. to coarse sand to med. gravel	121	131	Brown clay	131	137	Med. to coarse sand to med. gravel	137	160	Brown clay	160	185	Med. to coarse sand to med. gravel w/ clay lenses	185	221	Med. to coarse sand to med. gravel	221	277	Gray clay	277	284	Med. to coarse sand & gravel	284	294	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			2 Type and color of material	From	To																																																
			Top soil	0	2																																																
			Brown silty sand	2	26																																																
			Brown clay	26	31																																																
			Med. to coarse sand & gravel	31	76																																																
			Brown clay	76	94																																																
			Med. to coarse sand & gravel	94	105																																																
			Brown clay	105	121																																																
			Med. to coarse sand to med. gravel	121	131																																																
Brown clay	131	137																																																			
Med. to coarse sand to med. gravel	137	160																																																			
Brown clay	160	185																																																			
Med. to coarse sand to med. gravel w/ clay lenses	185	221																																																			
Med. to coarse sand to med. gravel	221	277																																																			
Gray clay	277	284																																																			
Med. to coarse sand & gravel	284	294																																																			
6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well																																																					
7 Casing: Material Stl Height: above 600 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 19.5 in. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																																																					
8 Screen: Manufacturer Doerr Type 16" Dia. 16" Slot/gauze 1/8 Length 100' Set between 195 ft. and 292 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2 x 3/8																																																					
9 Static water level: 76 ft. below land surface Date 2/17/75																																																					
10 Pumping level below land surfaces: No Test ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.																																																					
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____																																																					
12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade 12																																																					
13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> clay Depth: From 0 ft. to 10 ft.																																																					
14 Nearest source of possible contamination: None known ft. 2 mi Direction South Type Sub Barn Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																																																					
15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 12RKAH 100 Volt 460 Length of drop pipe 180 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																																					
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley																																																					
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name License No. Address 1011 W. Harry, Wichita Signed [Signature] Date 2/25/75																																																					

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5