

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Comanche	Fraction CSW 1/4 1/4 1/4	Section number 34	Township number T 31 S R 18 SW	Range number
2. Distance and direction from nearest town or city: 2 Mi. E. & 1 Mi. N. of Coldwater, Ks Street address of well location if in city:				3. Owner of well: Roy Boisseau R.R. or street: Coldwater, Kansas 67029 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>30</u> in. Completion date <u>7/26/78</u> Well depth <u>288</u> ft.		
		Well No. 4 (TH 1-78)		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Steel</u> Height: Above <u>below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.91</u> lbs./ft. Dia. <u>16</u> in. to <u>173</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>219</u>		
Sandy top soil		0	3	10. Screen: Manufacturer's name <u>Doerr</u> <u>Metal Products Co.</u> Type <u>Steel</u> Dia. <u>16"</u> Slot/gauze <u>1/8</u> Length <u>116'</u> Set between <u>173</u> ft. and <u>289</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/8x3/8</u>		
Fine to coarse sand - loose		3	78	11. Static water level: <u>109</u> ft. below land surface Date <u>7/26/78</u> mo./day/yr.		
Coarse sand - fine to coarse gravel		78	107	12. Pumping level below land surfaces: <u>161</u> ft. after <u>4</u> hrs. pumping <u>935</u> g.p.m. <u>205</u> ft. after <u>1</u> hrs. pumping <u>1500</u> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.		
Tan sandy clay		107	135	13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
Coarse sand		135	145	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
Tan sandy clay - sand streaks		145	171	15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Fine to coarse sand - small clay streaks		171	224	16. Nearest source of possible contamination: ft. <u>6000</u> Direction <u>west</u> Type <u>Farm</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Tan sandy clay		224	235	17. Pump: Not installed Manufacturer's name <u>Layne & Bowler Inc</u> Model number <u>12K</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>200</u> ft. capacity <u>900</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Fine to coarse sand		235	288	(Use a second sheet if needed)		
Redbed		288	320			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name <u>Wichita, Kansas</u> License No. <u> </u> Address <u> </u> Signed <u> </u> Date <u>8/4/78</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

31 18 34 CSW
 Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5