

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Comanche	Fraction C SW 1/4	1/4	1/4	Section number 35	Township number T 31	S	R	18	SW	
2. Distance and direction from nearest town or city: 3 Miles East & 1 Mile North of Coldwater Street address of well location if in city:						3. Owner of well: Mrs. Lee Turner Coldwater, Kansas R.R. or street: City, state, zip code:						
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile						Sketch map: Well No. 2						
5. Type and color of material						From	To		6. Bore hole dia. <u>30</u> in. Completion date <u>5/21/76</u> Well depth <u>266</u> ft.			
Sandy clay						0	5		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
Med. to coarse sand & gravel						25	95		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Clay						95	105		9. Casing: Material <u>Stl</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.91</u> lbs./ft. Dia. <u>16</u> in. to <u>178</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>219</u>			
Fine sand						105	115		10. Screen: Manufacturer's name <u>Doerr</u> <u>Metal Products</u> Type <u>Stl.</u> Dia. <u>16"</u> Slot/gauze <u> </u> Length <u>88'</u> Set between <u>178</u> ft. and <u>266</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>Yes</u> Size range of material <u>1/2 x 3/8</u>			
Clay						115	160		11. Static water level: <u>76</u> ft. below land surface Date <u>5/18/76</u> mo./day/yr.			
Fine to coarse sand						160	175		12. Pumping level below land surfaces: <u>152</u> ft. after <u>3.5</u> hrs. pumping <u>900</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>900</u> g.p.m.			
Clay						175	180		13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>			
Fine to coarse sand						180	189		14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade			
Sandy clay						189	200		15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
Fine to coarse sand & gravel						200	260		16. Nearest source of possible contamination: ft. <u>5000</u> Direction <u>South</u> Type <u>Farm</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Fine sand						260	265		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Layne</u> Model number <u>1146 WL</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>180</u> ft. capacity <u>900</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Green clay						265	268		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name License No. Address <u>Wichita, Kansas</u> Signed <u> </u> Date <u>6/22/76</u> Authorized representative			
Red clay						268	272					
(Use a second sheet if needed)												
18. Elevation:		19. Remarks:										
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley												

T
R
S
W
SW
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5