


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Comanche	Fraction SE 1/4 1/4 1/4	Section number 35	Township number T 31 S R 18	Range number 18
2. Distance and direction from nearest town or city: 4 miles East & 1 mile North of Coldwater Street address of well location if in city:			3. Owner of well: Mrs. Lee Turner R.R. or street: Coldwater, Kansas City, state, zip code:			
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map: Well No. 1			6. Bore hole dia. 30" in. Completion date _____ Well depth 215 ft. 5/18/76
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Sandy clay			0	4	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Fine sand			4	15	9. Casing: Material Stl Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 36.91 lbs./ft. Dia. 16 in. to 135 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; Gage No. 219	
Med. to co. sand & gravel w/clay			15	60	10. Screen: Manufacturer's name Doerr Metal Products Type Stl. Dia. 16" Slot/gauze 1/8" Length 80' Set between 135 ft. and 215 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8x7/8	
Clay			60	75	11. Static water level: 53 ft. below land surface Date 5/17/76 mo./day/yr.	
Med. to co. sand & gravel			75	95	12. Pumping level below land surfaces: 123 ft. after 3.5 hrs. pumping 800 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 800 g.p.m.	
Clay			95	130	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____	
Fine to coarse sand & fine to med. gr.			130	155	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
Sandy clay			155	175	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Med. to co. sand & gravel			175	188	16. Nearest source of possible contamination: ft. 0 Direction North Type Farm Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No	
Clay			188	190	17. Pump: _____ Not installed Manufacturer's name Layne Model number 7149WL HP 100 Volts _____ Length of drop pipe 180 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Med. to coarse sand & gravel			190	214	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name _____ License No. _____ Address Wichita, Kansas Signed Bill Hook Date 6/23/76 Authorized representative	
Red shale			214	220		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

31 18 35
 1/4 1/4 1/4
 CSE
 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5