

Giles

MT. JESUS

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ABC

1. Location of well:		County Clark	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 14	Township number T 31 S R	Range number 22 E W
2. Distance and direction from nearest town or city: 5 south-4 east-7 south of Kingsdown, Ks Street address of well location if in city:				3. Owner of well: Norman Lee Giles R.R. or street: Spearville, Kansas City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date _____ Well depth 104 ft. 4-21-77		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	3	9. Casing: Material Metal Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.66 lbs./ft. Dia. 16 in. to 104 ft. depth Wall Thickness: inch or Dia. _____ in. to _____ ft. depth gage No. .188		
Sandy clay		3	8	10. Screen: Manufacturer's name W.A. Brown		
Med. sand		8	10	Type 1 7/8 Free-flo Dia. 16 Slot/gauze 1/8 Length 80 Set between 18 ft. and 98 ft. _____ ft. and _____ ft.		
Clay		10	17	Gravel pack? Yes Size range of material 1/2 down		
Med. sand and gravel		17	56	11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 4-22-77		
Sandy brown clay		56	64	12. Pumping level below land surfaces: 70 ft. after 1 hrs. pumping 700 g.p.m. 50 ft. after 1 hrs. pumping 550 g.p.m. Estimated maximum yield 700 g.p.m.		
Half med. sand and gravel		64	75	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
Half med. sand and gravel with 20% clay		75	90	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> _____ Inches above grade		
Red bed shale		90	104	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Name of source of possible contamination: 100 ft. _____ Direction south Type well Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No _____		
				17. Pump: his used _____ Not installed Manufacturer's name Western Land Roller Model number 5 10M HP 50 Volts _____ Length of drop pipe 90 ft. capacity 750 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name _____ License No. _____ Address Dodge City, Ks Signed Carl G. Mittel Date 4-30-77 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		10 PD 2123 90 7033				

31 22 W 14 SURVIVE