


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

CATB

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Clark	Township name Appletown	Fraction NE SW	Section number 30	Town number 31	Range number 24
Distance and direction from nearest town or city: 10 miles S 1 1/2 E of Minneola, Ka.			3 Owner of well: Nathan Pike Address: Minneola, Kansas			
Locate with "X" in section below: 			Sketch map:			4 Well depth: 90 ft. Date of completion 6-19-75 Well diameter 5 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Surface			0	3	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> stock well	
Dark clay			3	10	7 Casing: plastic Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 1.6 lbs./ft. 5 in. to 90 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Colecho clay and sand rock			10	35	8 Screen: 50' screen Manufacturer superior Type 15 Dia. 5" Slot/gauze 7/16 Length 4" Set between 50 ft. and 90 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/8	
Fine sand			35	42	9 Static water level: 55 ft. below land surface Date 6-19-75	
Colecho clay			42	55	10 Pumping level below land surfaces: 75 ft. after 1 hrs. pumping 13 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 20 g.p.m.	
Clay			55	60	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
Fine sand			60	67	12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Fine sand some clay			67	75	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 70 ft.	
Medium sand and gravel			75	85	14 Nearest source of possible contamination: ft. Direction Type no Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Clay and gray shale			85	90	15 Pump: no stock <input type="checkbox"/> Not installed Manufacturer's name well Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. McCoy Drilling Co 190 Business name License No. Address Forbes Bldg. Topeka, Kas Signed Paul G. Little Date 6-30-75 Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope TOPO <input type="checkbox"/> Upland <input type="checkbox"/> Valley			2440 85 2355			