

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

C B E

1. Location of well:	County Meade	Fraction SW NW 1/4 1/4 SW 1/4	Section number 17	Township number T 31 S R 26 E/O	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: wheat field well Ornit building shed house corner 15		
5. Type and color of material			From	To	6. Bore hole dia. 8 1/2 in. Completion date 2-13-80 Well depth 69 ft.
topsoil			0	10	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
sand			11	20	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
sandrock + clay			21	60	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 69 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 40sch
gravel			61	69	10. Screen: Manufacturer's name Pump Co Type PVC Dia. 5" Slot/gauze 1/8" Length 20 Set between 69 ft. and 49 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/4-1/2"
white clay + sand Bentonite?			↓		11. Static water level: _____ mo./day/yr. 35 ft. below land surface Date 2-13-80
					12. Pumping level below land surfaces: 35 ft. after 1 1/2 hrs. pumping 25 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade
					15. Well grouted? Yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
					16. Nearest source of possible contamination: ft. 100 Direction E Type Corrals Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: F+W Not installed Manufacturer's name F+W Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other
			(Use a second sheet if needed)		
18. Elevation: 2486 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 2486 35 100		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Robert Bartel A101 Business name meade ks License No. _____ Address meade ks Signed Robert Bartel Date 3-28-80 Authorized representative		

T 31 S R 26 E
 Sec 17
 1/4 1/4 1/4 1/4
 SW NW