

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Meade	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 5	Township number T 31 S R 27 E/W	Range number
2. Distance and direction from nearest town or city: 4 1/2 west & 1 mi south of Fowler, Ks Street address of well location if in city:			3. Owner of well: John Hildebrand R.R. or street: Fowler, Kansas City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date <u>11-4-76</u> Well depth <u>364</u> ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From To		9. Casing: Material <u>Meta</u> Height: Above or below <u>10</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>31.66</u> in. RMP <u>16</u> PVC <input type="checkbox"/> Weight <u>31.66</u> lbs./ft. Dia. <u>16</u> in. to <u>364</u> ft. depth; Wall Thickness: inches or Dia. <u>16</u> in. to <u>364</u> ft. depth; gage No. <u>188</u>	
				10. Screen: Manufacturer's name <u>W.A. Brown & Cook</u> <u>35% Cook 17% Free-flo 16</u> Type <u>16</u> Dia. <u>16</u> Slot/gauze <u>1/8</u> Length <u>Cook 10 Free</u> -167 Set between <u>187</u> ft. and <u>364</u> ft. <u>187</u> ft. and <u>364</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/2 down</u>	
Surface		0 3		11. Static water level: <u>70</u> ft. below land surface Date <u>10-1-76</u>	
Brown, blue, green & gray clay		3 184		12. Pumping level below land surfaces: <u>150</u> ft. after <u>1</u> hrs. pumping <u>1000</u> g.p.m. <u>165</u> ft. after <u>1</u> hrs. pumping <u>1400</u> g.p.m. Estimated maximum yield <u>2500</u> g.p.m.	
Fine sand		184 186		13. Water sample submitted: <u>no.</u> /day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Sandy brown clay		186 199		14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
Fine to good sand and gravel		199 224		15. Well grouted? <u>no</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.	
Sandy coleche clay		224 229		16. Nearest source of possible contamination: ft. <u>600</u> Direction <u>west</u> Type <u>rock</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Med. sand and gravel		229 241		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Cemented sand and gravel		241 247		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Ace-Hi International 190</u> Business name _____ License No. _____ Address <u>Dodge City, Ks</u> Signed <u>Gail C. Stith</u> Date <u>11-10-76</u> Authorized representative	
Sandy brown clay		247 258			
Fine sand and gravel		258 261		(Use a second sheet if needed)	
Sandy coleche clay		261 287			
Good 1/2 to med. sand and gravel		287 296		18. Elevation:	
Sandy brown clay with 20% white rock		296 315		19. Remarks: 10' of concrete and pump slab to be installed by customer-he knows this is a regulation <i>John H. Hildebrand</i>	
Fine sand & sandrock with 15 to 20% clay		315 357			
Fine sand and 1/2 med. gravel		357 360			
Yellow and brown sandy clay		360 364			
Blue shale		364 375			

31 27 E
 R
 5
 SE SE SW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5