

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 7	Township number T 31 S R 27 E/W	Range number 27
2. Distance and direction from nearest town or city: 1 east-six north of Meade Street address of well location if in city:			3. Owner of well: Kenneth Padgett RFD R.R. or street: Fowler, Kansas 67844 City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		6. Bore hole dia. 28 in. Completion date 5-23-79 Well depth 376 ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Surface			0	3	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown and blue clay			3	91	9. Casing: Material metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 376 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219	
Sandrock with 30% clay mixed			91	98	10. Screen: Manufacturer's name W.A. Brown and cook Type 1 1/2" Free-fl. & 125 slot 16" Slot/gauze .125 & .100 length 189" Set between 187 ft. and 376 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 3/8 to #1	
Blue, brown and gray clay			98	129	11. Static water level: <input type="checkbox"/> flowing below land surface Date 5-24-79 mo./day/yr.	
Fine sand			129	135	12. Pumping level below land surfaces: 75 ft. after 2 hrs. pumping 900 g.p.m. 140 ft. after <input type="checkbox"/> hrs. pumping 2500 g.p.m. Estimated maximum yield 3000 g.p.m.	
Brown sandy clay with sandrock layers			135	153	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
Hard Layer			153	154	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
Fine sand with clay layers			154	179	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Gray clay			179	184	16. Nearest source of possible contamination: field ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Fine to med. sand			184	194	17. Pump: Not installed Manufacturer's name Goulds bowls-Redco head Model number 12JHC HP 84 Volts Length of drop pipe 200 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay			194	196	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. Address Dodge City, Kansas Signed Paul G. Antel Date 5-25-79 Authorized representative	
Fine to med. sand			196	204		
Brown and blue sandy clay			204	221		
Sandy clay with sandrock layers			221	233		
Fine to med. sand and gravel			233	246		
50% fine sand and gravel-50% clay			246	261		
Loose sand and gravel			261	263		
50% sand and gravel-50% clay			263	268		
Med. sand and fine gravel			268	286		
Sandy brown clay with coleche & sandrock layers			286	318		
Fine sand and sandrock			318	353		
Brown sandy clay			353	364		
Brown gravel with 30% clay mixed			364	370		
Yellow clay			370	372		
Blue shale			372	375		
(Use a second sheet if needed)						
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks:					

W
T
head
ST
Sec
7
SW
1/4
1/4
1/4
1/4
S
W
S
W
S
W

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5