

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

| | | | | | | |
|--|------------------------|---------------|-------------------------------|--|--------------------------|---------------------------|
| 1 Location of well: | County Meade | Township name | Fraction NW SE SW/4 | Section number 30 | Town number 31 | Range number 27 |
| Distance and direction from nearest town or city: Street address of well location if in city: | | | | 3 Owner of well: Lloyd Sneath Address: Meade, Kansas | | |
| Locate with "X" in section below: N W E S 1 Mile | | Sketch map: | | 4 Well depth: 218 ft. Date of completion 9-4-75 Well diameter 5 in. | | |
| 2 Type and color of material | | | | 5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary | | |
| | | | | 6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well | | |
| | | | | 7 Casing: Material 5" Height: Any /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. Diam. 5 in. Weight 220 lbs./ft. 100 to 218 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth! | | |
| | | | | 8 Screen: Manufacturer Jess & Lowell Type RMP Dia. 5" Slot/gauze 1/8" Length 40' Set between 178 ft. and 218 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4" | | |
| | | | | 9 Static water level: 51 ft. below land surface Date 8 9/04/75 | | |
| | | | | 10 Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 30 g.p.m. | | |
| | | | | 11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date | | |
| | | | | 12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade | | |
| | | | | 13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Cement Depth: From 4 ft. to 14 ft. | | |
| | | | | 14 Nearest source of possible contamination: hog pens ft. 75 Direction N Type hog pens Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| (use a second sheet if needed) | | | | 15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Aermotor Model number SD19 HP 1 Volts 230 Length of drop pipe ft. capacity 20 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| | | | | 16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley | | |
| 16 Remarks: elevation | | | | 17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 67864 Signed [Signature] Date 9-24-75 Authorized representative | | |