

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction NE 1/4 SW 1/4 SE 1/4	Section number 2	Township number T 31 S R 28 E 10
2. Distance and direction from nearest town or city: 6 N. 1 E of Meade			3. Owner of well: Hartshorn Seed Yard		
Street address of well location if in city:			R.R. or street:		
4. Locate with "X" in section below:			City, state, zip code: Meade, Kansas 67864		
Sketch map: 		6. Bore hole dia. 8 1/2 in. Completion date _____ Well depth 360 ft. 8-3-79			
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
topsoil		0	5	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
clay		6	60	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 360 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 40 each	
sandy clay		61	175	10. Screen: Manufacturer's name Jet Stream Type PVC Dia. 5" Slot/gauze 7/16" Length 40' Set between 320 ft. and 360 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/4"-1/2"	
sand/gravel/clay		176	180	11. Static water level: _____ mo./day/yr. 76 ft. below land surface Date 8-3-79	
sandy clay		181	200	12. Pumping level below land surfaces: 76 ft. after 1 1/2 hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.	
sand		201	210	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
sandy clay		211	255	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade	
clay		256	295	15. Well grouted? Yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 15 ft.	
sandy clay		276	290	16. Nearest source of possible contamination: ft. 100 Direction S Type feedlot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
clay		281	300	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
gravel		301	310	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bertil Bily 101 A Business name Meade, Ko License No. _____ Address Meade, Ko Signed Steve P. Bertil Date 12-27-79 Authorized representative	
clay		311	330		
sandy clay		331	360		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5