

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

<input checked="" type="checkbox"/> 1. Location of well:	County Meade County	Fraction 1/4 1/4 NW 1/4	Section number 5	Township number T 31 S R	Range number 28 E/W
<input checked="" type="checkbox"/> 2. Distance and direction from nearest town or city:	3. Owner of well: Wallace McCune		R.R. or street: Meade, KS 67864		
4. Locate with "X" in section below:		Sketch map: <i>6 1/2 N of Meade, 3/4 West, 1/4 South</i>		6. Bore hole dia. <u>26</u> in. Completion date <u>11-18-77</u> Well depth <u>385</u> ft.	
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>1 ft.</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>385</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>219</u>		10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Johnson Galv.</u> Dia. <u>100-16"</u> Slot/gauze <u>0-190 Plain</u> Dia. <u>190-280 Perf.</u> Set between <u>280-300</u> Screen <u>300-370</u> Perf. 370-380 Screen 380-385 Perf. Gravel pack? <u>yes</u> Size range of material <u>3/4 to 5/8</u>	
5. Type and color of material		From	To	11. Static water level: <input type="checkbox"/> mo./day/yr. <u>134</u> ft. below land surface Date <u>10-20-77</u>	
				12. Pumping level below land surfaces: <u>155</u> ft. after <u>2</u> hrs. pumping <u>1100</u> g.p.m. <u>166</u> ft. after <u>4</u> hrs. pumping <u>1650</u> g.p.m. Estimated maximum yield <u>1650</u> g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ mo./day/yr.	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>1 ft.</u> inches above grade	
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination: ft. _____ Direction <u>N/A</u> Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Gould 3 stg. 14"</u> Model number _____ HP <u>200</u> Volts _____ Length of drop pipe <u>220</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter-Wilson Drlg. Co. 208</u> Business name License No. _____ Address <u>Box A, Garden City, KS 67846</u> Signed <u>Wallace McCune</u> Date <u>11-19-77</u> Authorized representative	
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

31 28 E - 5 CMB
T
R
W
E
S
E
C
M
B

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

WALLACE MCCONE
MEADE COUNTY
7-22-77

Location: NW 5-31-28 1 south fowler jct., 3 west 3/4
north on east side of road

Static Water Level- 135'

Test #1

0	3	Top soil
3	36	Brown clay
36	51	Fine sand and gravel
51	79	Fine to med. sand and gravel
79	96	Brown clay
96	256	Fine to med. sand and gravel
256	264	Blue clay
264	269	Brown clay
269	321	Fine to med. sand and gravel
321	327	Brown sand sandy clay
327	342	Fine to med. sand and gravel
342	352	Brown sandy clay
352	380	Fine to med. sand and gravel
380	394	Brown clay
394	440	Brown clay and white rock
440	462	Fine sand and brown rock 15% clay
462	478	Brown clay and white rock
478	482	Brown and yellow clay and brown rock
482	485	Shale

385'

T.D. 380'

Screen