


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment  
Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>MEADE</b>	Fraction <b>SE 1/4 NW 1/4 SE 1/4</b>	Section number <b>8</b>	Township number <b>T 31 S</b>	Range number <b>R 29 W</b>
2. Distance and direction from nearest town or city: <b>South of Copeland</b> Ks. to <b>2 1/2</b> miles <b>5</b> East, <b>5</b> South East, <b>1/2</b> South, <b>1/2</b> West			3. Owner of well: <b>Robert Pennington</b> R.R. or street: <b>505 N. Spring Lake</b> City, state, zip code: <b>Meade, Ks. 67864</b>			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		6. Bore hole dia. <b>26</b> in. Completion date <b>11-11-75</b> Well depth <b>442</b> ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>4 1/8</b> depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>	
					10. <b>Johnson Manufacturing Co.</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauge Length <b>20'</b> Set between <b>300-310</b> ft. and <b>390-400</b> ft. Perf. <b>200-300</b> and <b>310-390, 400-412</b> Gravel pack? <b>yes</b> Size range of material <b>1/2" Down</b>	
					11. Static water level: <b>11</b> <del>11.2</del> <b>11</b> <del>11.2</del> <b>11</b> <del>11.2</del> ft. below land surface Date <b>11-20-75</b>	
					12. Pumping level below land surfaces: <b>818</b> <b>152</b> ft. after <b>2</b> hrs. pumping <b>1245</b> g.p.m. <b>162</b> ft. after <b>4</b> hrs. pumping <b>1245</b> g.p.m. Estimated maximum yield <b>1215</b> g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
					14. Well head completion: <b>12</b> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					15. Well grouted? <b>yes</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
					16. Nearest source of possible contamination: <b>N/A</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <b>Not installed</b> Manufacturer's name <b>Goulds US Pumps</b> Model number <b>11JHC</b> HP <b>200</b> Volts <input type="checkbox"/> Length of drop pipe <b>280</b> ft. capacity <b>1200</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Miner-Wilson Drilling 208</b> Business name <b>D.B.A. Garden City</b> Office No. <input type="checkbox"/> Address <input type="checkbox"/> Signed <b>[Signature]</b> Date <b>5-15-75</b> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

75

12

37  
 29  
 8  
 SE  
 1/4  
 1/4 NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The*  
*Professionals*

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Robert Pennington  
Meade County  
10-9-75

Location: SE 8-31-29  
5 miles South of Chester Rexford's House, 1 mile  
East, ½ mile South, 200 ft. East of NW corner of  
Quarter

Test # 1

0	4	Top Soil
4	20	Brown Clay
20	42	White & Brown Sandy Clay
42	50	Fine to Med. Sand (Tight)
50	77	White & Brown Sandy Clay
77	127	Fine to Med. Sand & Gravel (Loose)
127	140	Brown Sandy Clay
140	322	Fine to Med. Sand & Gravel (Loose)
322	333	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
333	334	Hard Streak
334	350	Fine to Med. Sand & Gravel, Streaks of Clay & White Rock (10%)
350	400	Fine to Med. Sand & Gravel (Loose)
400	412	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
412	440	Fine sand mixed with Brown & White Sandy Clay (Tight)

TD 412'