

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

|   |  |                        |  |                             |   |   |
|---|--|------------------------|--|-----------------------------|---|---|
| 1. Location of well:  |  | County<br><b>Meade</b> | Fraction<br><b>SW 1/4 SW 1/4 SE 1/4</b>  | Section number<br><b>10</b> | Township number<br><b>T 31 S R 29</b>   | Range number<br><b>E 10</b>   |
| 2. Distance and direction from nearest town or city: <b>6.5 miles W &amp; 5 miles N of Meade, Kansas</b><br>Street address of well location if in city: |  |                        | 3. Owner of well: <b>James Stevens</b><br>R.R. or street: <b>% Holmes Carol Bender</b><br>City, state, zip code: <b>Plains, Kansas</b> |                             |   |   |
| 4. Locate with "X" in section below:<br>N<br>W<br>E<br>S<br>1 Mile<br>1 Mile  |  |                        | Sketch map:<br><b>SW corner of the SE 1/4, Sec. 10, T31S, R29W, Meade Co., Kansas</b>  |                             |   | 6. Bore hole dia. <b>28</b> in. Completion date <b>5-20-76</b><br>Well depth <b>438</b> ft. |
| 5. Type and color of material   |  |                        | From   | To                          | 7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug<br><input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary   |   |
| Top soil  |  |                        | 0  | 3                           | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry<br><input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock<br><input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other  |   |
| Tan clay fine silty sand streaks  |  |                        | 3  | 110                         | 9. Casing: Material <b>STL</b> Height: <u>Above or below</u><br>Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in.<br>RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>37</b> lbs./ft.<br>Dia. <b>16</b> in. to <b>194</b> ft. depth Wall Thickness: inches or<br>Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>219</b>  |   |
| Coarse sand fine to med, gravel   |  |                        | 110  | 128                         | 10. Screen: Manufacturer's name <b>Doerr, Brown and Foster</b><br>Type <b>Louver &amp; Millslet</b> Dia. <b>16"</b><br>Slot/gauze <b>1/8"</b> Length <b>244'</b><br>Set between <b>194</b> ft. and <b>438</b> ft.<br><input type="checkbox"/> ft. and <input type="checkbox"/> ft.<br>Gravel pack? <b>Yes</b> Size range of material <b>4.4mm</b>   |   |
| Fine to coarse sand   |  |                        | 128  | 194                         | 11. Static water level: <input type="checkbox"/> mo./day/yr.<br><b>142</b> ft. below land surface Date <b>8-27-75</b>   |   |
| Gray clay   |  |                        | 194  | 200                         | 12. Pumping level below land surfaces:<br><b>170</b> ft. after <b>1</b> hrs. pumping <b>1641</b> g.p.m.<br><b>184</b> ft. after <b>1</b> hrs. pumping <b>2400</b> g.p.m.<br>Estimated maximum yield <b>2750</b> g.p.m.  |   |
| Fine to coarse sand fine gravel streaks   |  |                        | 200  | 264                         | 13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>   |   |
| Fine to coarse sand clay streaks  |  |                        | 264  | 324                         | 14. Well head completion:<br><input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <input type="checkbox"/> Inches above grade   |   |
| Tan and white clay  |  |                        | 324  | 334                         | 15. Well grouted? <b>Yes</b><br>With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete<br>Depth: From <b>0</b> ft. to <b>10</b> ft.   |   |
| Fine to coarse sand   |  |                        | 334  | 382                         | 16. Nearest source of possible contamination: <b>Unk</b><br>ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/><br>Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No  |   |
| Tan clay  |  |                        | 382  | 394                         | 17. Pump: <input type="checkbox"/> Not installed<br>Manufacturer's name <b>Layne &amp; Bowler</b><br>Model number <b>14TL</b> HP <b>150</b> Volts <input type="checkbox"/><br>Length of drop pipe <b>240</b> ft. capacity <b>2000</b> g.p.m.<br>Type:<br><input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine<br><input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating<br><input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |   |
| Fine to coarse sand   |  |                        | 394  | 402                         | 20. Water well contractor's certification:<br>This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.<br><b>Layne - Western Co.</b> 150<br>Business name License No.<br>Address <b>Garden City</b><br>Signed <b>[Signature]</b> Date <b>5-21-76</b><br>Authorized representative  |   |
| Tan and white clay (Use a second sheet if needed)   |  |                        | 402  | 410                         | 18. Elevation:  |   |
| Fine to coarse sand   |  |                        | 410  | 420                         | 19. Remarks:  |   |
| Tan and white clay  |  |                        | 420  | 430                         | Topography:<br><input type="checkbox"/> Hill<br><input type="checkbox"/> Slope<br><input checked="" type="checkbox"/> Upland<br><input type="checkbox"/> Valley   |   |
| Fine to coarse sand   |  |                        | 430  | 438                         | 1/4 1/4 1/4 1/4   |   |
| Tan and white clay  |  |                        | 438  | 460                         | 1/4 1/4 1/4 1/4   |   |

T 31 S R 29 E 10 Sec 10

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5