


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Meade	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 10	Township number T 31 S R 29 E	Range number 29
2. Distance and direction from nearest town or city: Meade, Kansas Street address of well location if in city: 7W & 5 N of			3. Owner of well: James Stevens R.R. or street: % Holmes Carol Bender City, state, zip code: Plains, Kansas		
4. Locate with "X" in section below: Sketch map:  SW corner of the SW 1/4, Sec, 10, T31S, R29W, Meade Co., Kansas			6. Bore hole dia. 28 in. Completion date 5-10-76 Well depth 422 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			9. Casing: Material Stl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 197 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219		
Top soil			10. Screen: Manufacturer's name Doerr, Brown and Foster Type Louver & Millslot Dia. 16" Slot/gauze 1/8" Length 225' Set between 197 ft. and 422 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 4.4mm		
Tan clay			11. Static water level: <input type="checkbox"/> mo./day/yr. 142 ft. below land surface Date 8-26-75		
Fine to coarse sand med. gravel with tan clay			12. Pumping level below land surfaces: 154 ft. after 1 hrs. pumping 1641 g.p.m. 160 ft. after 1 hrs. pumping 2700 g.p.m. Estimated maximum yield 3000 g.p.m.		
Fine to coarse sand med. gravel			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Green clay			14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <input type="checkbox"/> Inches above grade		
Fine to coarse sand med. gravel			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Tan clay with sand streaks			16. Nearest source of possible contamination: Unk ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Fine to coarse sand med. gravel			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 14TL HP 150 Volts <input type="checkbox"/> Length of drop pipe 240 ft. capacity 2000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Green Clay			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne - Western Co. 150 Business name License No. Address Garden City Signed R. L. Vincent Date 5-21-76 Authorized representative		
Fine to coarse sand med. gravel			18. Elevation:		
White and tan clay			19. Remarks: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
(Use a second sheet if needed)					

31 29 W 10 S W 1/4 1/4 9/14

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5