


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Meade	Fraction SE 1/4 NE 1/4 SW 1/4	Section number 19	Township number T 31 S R 29	Range number 19W
2. Distance and direction from nearest town or city: south of Copeland to 2nd. curve, 9 south, 4 east, 1/2 south			3. Owner of well: Chester Rexford R.R. or street: Meade, Ks. 67864 City, state, zip code:		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 26 in. Completion date 3-14-77 Well depth 370 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 37 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .250		
			10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20 ft. Set between 340 ft. and 360 ft. Perf: 200-340 ft. and 360-370 ft. Gravel pack? yes Size range of material 1/2" down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 136 ft. below land surface Date 1-27-77		
			12. Pumping level below land surfaces: 177 ft. after 2 hrs. pumping 900 g.p.m. 197 ft. after 4 hrs. pumping 1400 g.p.m. Estimated maximum yield 1400 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds- US Pump Model number 12 THC HP 200 Volts Length of drop pipe 260 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. Address Box A Gardner City, Ks. Signed <i>[Signature]</i> Date 5-13-77 Authorized representative		

31 29 W 19 SE NESW 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHESTER REXFORD
MEADE COUNTY
1/4/77

Location: SW 19-31-29 1/8 mile north of No. 1

Static Water Level- 155'

Test #2

0	1	Top soil
1	38	Brown clay
38	107	Brown clay and white rock tight
107	147	Fine to med. sand and gravel Loose
147	155	Fine to med. sand and gravel 10% clay Loose
155	245	Fine to med. sand and gravel Loose
245	257	Fine to med. sand and gravel 15% clay Loose
257	279	Fine to med. sand and gravel Loose
279	290	Fine to med. sand and gravel 10% clay Loose
290	370	Fine to med. sand and gravel Loose
370	376	Brown and gray clay with white rock hard
376	402	Brown and gray clay tight
402	434	Brown and gray clay small streaks of gravel 30% Fairly Loose
434	440	Fine to med. sand and gravel Loose
440	455	Brown and gray clay with white rock Hard

T.D. 370