

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 19	Township number T 31 S	Range number R 29	1/W
2. Distance and direction from nearest town or city: South of Copeland to 2nd curve, 9 South 5 East, 1/2 South				3. Owner of well: Dean Borth R.R. or street: Meade, Ks. City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 10-10-75 Well depth 465 ft.			
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material		From	To	9. Casing: Material _____ Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 36.12 in. RMP _____ PVC _____ Weight 36.87 lbs./ft. Dia. 16 in. to 466 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____			
				10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16 in. Slot/_____ Length 440-450 Set between 370-380 ft. and 440-450 ft. Peri. 200-370 ft. and 380-440-450 ft. Gravel pack <input checked="" type="checkbox"/> Size range of material 1/2" Down			
				11. Static water level: _____ mo./day/yr. 136 ft. below land surface Date 10-10-75			
				12. Pumping level below land surfaces: _____ ft. after 2 hrs. pumping 805 g.p.m. _____ ft. after 4 hrs. pumping 1390 g.p.m. Estimated maximum yield 1390 g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____			
				14. Well head completion: _____ <input type="checkbox"/> Pitless adapter 12 Inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.			
				16. Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No _____			
				17. Pump: Cess Goulds Install Pumps Manufacturer's name _____ Model number K-2178 HP 200 1390 g.p.m. Length of drop pipe 240 ft. capacity _____ g.p.m. Type: _____ <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other _____			
				(Use a second sheet if needed)			
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 200 Business name License No. _____ Address P.O. Box 4, Garden City, Ks. Signed [Signature] Date 10-30-75 Authorized representative					

136
 296
 1390
 Sec 19
 NESUMNE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Dean Borth
Meade County
10-1-75

Location: NE 19-31-29, 1/4 mile west of Test # 1

Test # 2

0	4	Top Soil
4	10	Brown Clay
10	42	Brown Sandy Clay
42	73	Brown Sandy Clay mixed with white Clay
73	101	Brown Sandy Clay
101	156	Fine to Med. Sand & Gravel (Loose)
156	160	Gray & Brown Clay
160	380	Fine to Med. Sand & Gravel (Loose)
380	403	Brown Sandy Clay
403	410	Fine to Med. Sand (Loose)
410	427	Fine Sand, Streaks of Clay (10%) (Tight)
427	465	Fine to Med. Sand & Gravel (Loose)
465	500	Gray & Brown Clay (Tight)

TD 465'