


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>MEADE</b>	Fraction <b>SE 1/4 NW 1/4 SW 1/4</b>	Section number <b>28</b>	Township number <b>T 31 S</b>	Range number <b>R 29 E</b>
2. Distance and direction from nearest town or city: <b>1/4 south 1/2 west 1/4 north, 1/4 east of Missler</b> Street address of well location if in city:				3. Owner of well: <b>Roy Whitehead</b> R.R. or street: <b>Meade, Ks. 67864</b> City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>6-25-76</b> Well depth <b>470</b> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <b>steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>470</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
				10. Screen: Manufacturer's name <b>Johnson Division</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauze <b>100</b> Length <b>20'</b> Set between <b>380</b> ft. and <b>400</b> ft. <b>Perf</b> <b>180-320</b> ft. and <b>350-380, 400-410</b> Gravel pack? <b>yes</b> Size range of material <b>1/4" Down</b>		
				11. Static water level: <input type="checkbox"/> mo./day/yr. <b>136</b> ft. below land surface Date <b>5-19-76</b>		
				12. Pumping level below land surfaces: <b>150</b> ft. after <b>3</b> hrs. pumping <b>1475</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>1475</b> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade		
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>30</b> ft.		
				16. Nearest source of possible contamination <b>N/A</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Goulds US Pumps</b> Model number <b>12IB</b> HP <b>200</b> Volts <input type="checkbox"/> Length of drop pipe <b>200</b> ft. capacity <b>1000</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Winter Wilson Drilling 208</b> Business name <b>P.O. Box 1 Garden City, Mo.</b> Address <b>19-76</b> Signed <b>[Signature]</b> Date <b>19-76</b> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The*  
**Professionals**

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

ROY WHITEHEAD  
MEADE COUNTY  
4-26-76

Location: SE 28-31-29  
From Missler Elevator first road south,  $2\frac{1}{2}$  miles  
west,  $\frac{1}{4}$  mile north,  $\frac{1}{4}$  mile east, 30 ft. west of  
Pivot.

Static Water Level: 140'

Test # 1

0	3	Top Soil
3	5	Brown Clay
5	20	Brown Sandy Clay
20	124	Brown & White Sandy Clay
124	140	Brown & White Clay, Streaks of Fine to Med. Sand & Gravel (30%)
140	190	Fine to Med. Sand & Gravel (Loose)
190	198	Fine to Med. Sand & Gravel, Streaks of White Rock (10%)
198	308	Fine to Med. Sand & Gravel (Loose)
308	316	Fine to Med. Sand, Streaks of Clay (Blue & Brown 20%)
316	350	Blue & Brown Clay
350	400	Fine to Med. Sand & Gravel (Loose)
400	410	Fine to Med. Sand & Gravel, Streaks of Clay (10%) (Loose)
410	427	Brown, White & Gray Clay
427	430	Yellow & Gray Clay (Tight)

T.D. - 410'