

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sumner	Fraction 1/4 NW 1/4 SE 1/4	Section number 6	Township number T 31 S	Range number R 3 E
2. Distance and direction from nearest town or city: 1 1/2 West of Conway Springs, and 1/4 mile South of the road.			3. Owner of well: Max Crowell R.R. or street: Route #2 City, state, zip code: Conway Springs, Kansas			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: Conway Springs, Ks.			
5. Type and color of material			From	To	6. Bore hole dia. 11 in. Completion date 12-15-76 Well depth 60 ft.	
Sandy Soil			0	1	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Fine Sand			1	16	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Red Shale			16	60	9. Casing: Material styrene Height: Above or below 11 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness .200 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. .200	
					10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/size .06 Length 40' Set between 20 ft. and 60 ft. Gravel pack? yes Size range of material 1-1/8"	
					11. Static water level: 15 ft. below land surface Date 12-15-76 mo./day/yr.	
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____	
					14. Well head completion: 12 capped ____ Pitless adapter ____ Inches above grade	
					15. Well grouted? yes <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40' ft. to 14 ft.	
					16. Nearest source of possible contamination: None ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other	
18. Elevation:			19. Remarks: Flat Ground Septic Tank not installed when the well was drilled. No apparent source for contamination.			
Topography: ____ Hill ____ Slope ____ Upland ____ Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas license No. ____ Address ____ Signed M. Arnold Date 1-8-77 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5